



# Certificate of Conformity

Certificate Number: CN-PV-240029

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Shenzhen PolarESS Technology Co., Ltd. 6#-1002, Building 6, Chuangwei Innovation Valley, No.8 Tangtou 1st Road, Tangtou Community, Shiyan Sub-district, Bao'an District, Shenzhen, China.
<b>Product:</b>	PV Hybrid Inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	ALPS HY3.6-GL, ALPS HY4.6-GL, ALPS HY5.0-GL, ALPS HY6.0-GL
<b>Brand Name&lt;s&gt;:</b>	
<b>Product Complies with:</b>	NRS 097-2-1:2017 Edition 2.1 GRID INTERCONNECTION OF EMBEDDED GENERATION PART 2: SMALL-SCALE EMBEDDED GENERATION SECTION 1: UTILITY INTERFACE
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	231207123GZU-001, 23 Jan 2024

Additional information in Appendix.



Signature

**Certification Manager: Grady Ye**  
**Date: 26 January 2024**



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-240029

Model	ALPS HY3.6-GL	ALPS HY4.6-GL	ALPS HY5.0-GL	ALPS HY6.0-GL
Input Data (PV)				
Max. PV open-circuit voltage	550 V			
Max. PV short-circuit current	2*23 A			
Max. PV input current	2*17 A			
MPPT voltage range	90~530 V			
MPPT tracker/No. of Strings per MPP Tracker	2/1			
Output Data (AC, on-grid)				
Rated AC output power	3600 W	4600 W	5000 W	6000 W
Max. apparent power	3600 VA	4600 VA	5000 VA	6000 VA
Max. output current	16 A	20 A	21.7 A	26 A
Nominal grid voltage	230Va.c.			
Nominal frequency	50/60 Hz			
Power factor range	0.8 lagging ~ 0.8 leading			
Output Data (AC, backup)				
Nominal EPS output power	3600 W	4600 W	5000 W	6000 W
AC Nominal voltage	230Va.c.			
Nominal frequency	50Hz			
Max. output current	16 A	20 A	21.7 A	26 A
Battery				
Battery type	Lead-acid or Li-ion			
Battery voltage range	46.7-57.6 V			
Nominal voltage	51.2 V			
Max. charging/ discharging current	83A/83A	104A/ 104A	112A/ 112A	130A/ 130A
Max. Battery charging/discharging power	4000W/ 4000W	5000W/ 5000W	5400W/ 5400W	6500W/ 6500W
Others				
Inverter Topology	Non-isolated			
Overvoltage Category	DC II; AC III			
Ingress protection	IP20			
Protective Class	Class I			
Operating temperature range	-25℃~60℃			
Software version	SD1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.