

ATTESTATION OF CONFORMITY

Issued to: Blue Mountain Energy Ltd
Crown House, 27 Old Gloucester Street, London, WC1N 3AX

For the product: Grid-connected PV Inverter

Trade name:  KODAK

Type/Model: I3.0, I3.6, I4.6

Ratings: I3.0
PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x11A,
Isc PV: 2x17,2A
AC output: 230V, 50/60Hz, max 15,7A, rated 3000W, max 3300VA
I3.6
PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x11A,
Isc PV: 2x17,2A
AC output: 230V, 50/60Hz, max 16A, rated 3600W, max 4000VA
I4.6
PV input: max 600Vdc, MPP voltage range: 90-520Vdc, max 2x11A,
Isc PV: 2x17,2A
AC output: 230V, 50/60Hz, max 23,8A, rated 4600W, max 5000VA

Manufactured by: Blue Mountain Energy Ltd
Crown House, 27 Old Gloucester Street, London, WC1N 3AX

Requirements: NRS 097-2-1:2017

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 6065813.50.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 10 December 2019

Number: 6065813.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.


Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd.
3F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Jing'an District, Shanghai 200436 China
T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-certification.com