



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

Holder of Certificate: **Ningbo Ginlong Technologies Co., Ltd.**

No.57 Jintong Road
Binhai Industrial Park, Xiangshan
315712 Ningbo, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
PV Grid Tied Inverter**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. See also notes overleaf.

Test report no.: 704091907610-00

Date, 2019-11-06


(Zhengdong Ma)



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

Model(s):

Solis-1P2.5K-4G, Solis-1P3K-4G,
Solis-1P3.6K-4G, Solis-1P4K-4G,
Solis-1P4.6K-4G.

Parameters:

Max. input voltage:	550 Vd.c. (Solis-1P2.5K-4G) 600 Vd.c. (Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G)
Mppt voltage range:	50 – 450 Vd.c. (Solis-1P2.5K-4G) 90 – 520 Vd.c. (Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G)
Max. input current:	2 x 11 A
Isc PV(absolute maximum):	2 x 17,2 A
Rated grid voltage:	230 V~
Rated grid frequency:	50 Hz
Rated output power:	2500 W (Solis-1P2.5K-4G), 3000 W (Solis-1P3K-4G), 3600 W (Solis-1P3.6K-4G), 4000 W (Solis-1P4K-4G), 4600 W (Solis-1P4.6K-4G)
Max. AC output active power:	2800 W (Solis-1P2.5K-4G), 3300 W (Solis-1P3K-4G), 4000 W (Solis-1P3.6K-4G), 4400 W (Solis-1P4K-4G), 4600 W (Solis-1P4.6K-4G)
Max. AC output apparent power:	2800 VA (Solis-1P2.5K-4G), 3300 VA (Solis-1P3K-4G), 4000 VA (Solis-1P3.6K-4G), 4400 VA (Solis-1P4K-4G), 4600 VA (Solis-1P4.6K-4G)
Max. continuous output current:	13,3 A (Solis-1P2.5K-4G), 15,7 A (Solis-1P3K-4G), 16 A (Solis-1P3.6K-4G), 21 A (Solis-1P4K-4G), 23,8 A (Solis-1P4.6K-4G)
Adjustable displacement factor:	-0,8...1...+0,8
Operating temperature Range:	-25 °C...+60 °C
Protective Class:	I
Ingress Protection:	IP65



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

E.4 Unit certificate

Unit certificate	No. 70.409.19.076.10-00		
Manufacturer	Ningbo Ginlong Technologies Co., Ltd. No.57 Jintong Road, Binhai Industrial Park, Xiangshan, 315712 Ningbo, Zhejiang, PEOPLE'S REPUBLIC OF CHINA		
Power generation unit type	Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G Remark: certified on representative model Solis-1P4.6K-4G of family design products, results of the measurement of Solis-1P4.6K-4G can be transferred to other type of power generation units based on transferability rule of measurements in E DIN VDE V 0124-100 (VDE V 0124-100):2019.		
☒ Inverter	☐ Asynchronous generator	☐ Synchronous generator	
☐ Stirling generator	☐ Fuel cell	☐ others	
Assessment values	Max. active power $P_{E_{max}}$	4561 W (Solis-1P4.6K-4G)	
	Max. apparent power $S_{E_{max}}$	4565 VA (Solis-1P4.6K-4G)	
	Rated voltage	230 V~	
Rated values	Rated current (AC) I_r	23,8 A(Solis-1P4.6K-4G)	
Rated values	Initial short-circuit current I_k "	23,8 A(Solis-1P4.6K-4G)	
Network connection rules	VDE-AR-N 4105 "Power generation systems connected to the low-voltage network" Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network		
Test requirement	E DIN VDE V 0124-100 (VDE V 0124-100) "Network integration of power generation system – Low voltage" Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network		
The above mentioned power generation unit meets the requirements of VDE-AR-N 4105.			



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

E.5 Test report "Network interactions " for generating units with an input current > 75 A

Extract from test report for unit certificate "Determination of electrical properties"		No. 70.409.19.076.10-00
Generation unit manufacturer:	Ningbo Ginlong Technologies Co., Ltd. No.57 Jintong Road, Binhai Industrial Park, Xiangshan, 315712 Ningbo, Zhejiang, PEOPLE'S REPUBLIC OF CHINA	
Manufacturer indications:	Type of system	Grid-Connected Inverter for PV system
	Max. active power P _{Emax}	4600 W (Solis-1P4.6K-4G)
	Rated voltage	230 V~
Period of measurement:	From 2019-09-01 to 2019-10-19	
-		
Rapid voltage change (Solis-1P4.6K-4G)		
Connection without provisions (regarding the primary energy carrier)		k _i =0,14
Most adverse case when switching between generator levels Remark: Not applicable for PV system		N/A
Connection at nominal conditions (of the primary energy carrier)		k _i =0,94
Disconnection at rated power		k _i =0,94
Worst case value of all switching operations		k _{i max} =0,94

Flicker – IEC 61000-3-11 (Solis-1P4.6K-4G)	$d(t) - 500ms [\%]$	$d_c [\%]$	$d_{max} [\%]$	P_{st}	P_{lt}	$c(\psi_k)$
	0	0,40	0,49	0,07	0,65	8,67



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

Harmonics – IEC 61000-3-2 (Solis-1P4.6K-4G)											
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100
Ordinal number	I [A]	I [A]	I [A]	I [A]	I [A]	I [A]	I [A]	I [A]	I [A]	I [A]	I [A]
2	0,06	0,07	0,06	0,06	0,06	0,06	0,07	0,08	0,09	0,10	0,10
3	0,18	0,23	0,18	0,17	0,17	0,17	0,21	0,23	0,26	0,28	0,28
4	0,03	0,03	0,02	0,02	0,02	0,02	0,02	0,02	0,02	0,02	0,02
5	0,09	0,04	0,09	0,09	0,10	0,11	0,16	0,19	0,22	0,23	0,23
6	0,02	0,02	0,02	0,01	0,01	0,01	0,02	0,02	0,01	0,01	0,01
7	0,07	0,04	0,07	0,10	0,11	0,12	0,15	0,17	0,18	0,19	0,20
8	0,01	0,01	0,01	0,01	0,01	0,00	0,01	0,01	0,01	0,01	0,01
9	0,03	0,06	0,04	0,06	0,07	0,08	0,11	0,12	0,14	0,14	0,14
10	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01
11	0,04	0,05	0,04	0,06	0,07	0,08	0,10	0,11	0,12	0,12	0,12
12	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,01	0,01	0,01
13	0,01	0,02	0,03	0,04	0,05	0,05	0,07	0,08	0,08	0,09	0,09
14	0,01	0,01	0,01	0,01	0,02	0,01	0,02	0,02	0,02	0,02	0,01
15	0,02	0,02	0,03	0,03	0,04	0,04	0,06	0,06	0,07	0,07	0,07
16	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02
17	0,01	0,02	0,02	0,02	0,02	0,02	0,04	0,04	0,05	0,06	0,06
18	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02
19	0,01	0,01	0,02	0,01	0,01	0,01	0,03	0,04	0,04	0,05	0,05
20	0,01	0,01	0,02	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02
21	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,03	0,04	0,04	0,04
22	0,02	0,02	0,02	0,02	0,02	0,02	0,02	0,02	0,02	0,02	0,03
23	0,01	0,01	0,01	0,01	0,00	0,01	0,02	0,02	0,03	0,04	0,04
24	0,02	0,02	0,02	0,02	0,01	0,02	0,02	0,02	0,02	0,02	0,03
25	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,03	0,03
26	0,02	0,02	0,02	0,02	0,01	0,02	0,02	0,02	0,03	0,03	0,03
27	0,01	0,02	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02
28	0,02	0,02	0,02	0,02	0,01	0,02	0,02	0,02	0,02	0,02	0,02
29	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02
30	0,03	0,03	0,02	0,02	0,01	0,02	0,03	0,02	0,02	0,03	0,03
31	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02
32	0,02	0,02	0,02	0,02	0,01	0,02	0,02	0,02	0,03	0,03	0,03
33	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,02
34	0,02	0,03	0,02	0,02	0,00	0,02	0,02	0,02	0,03	0,03	0,03
35	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01
36	0,03	0,02	0,02	0,03	0,01	0,03	0,03	0,03	0,03	0,04	0,04
37	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01
38	0,03	0,03	0,02	0,03	0,01	0,02	0,03	0,03	0,03	0,03	0,04
39	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01
40	0,03	0,02	0,02	0,02	0,02	0,02	0,02	0,02	0,03	0,03	0,03



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

Harmonics – IEC 61000-3-12 (Solis-1P4.6K-4G)											
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100
Ordinal number	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2	0,31	0,33	0,30	0,31	0,29	0,32	0,37	0,41	0,46	0,49	0,52
3	0,90	1,13	0,91	0,85	0,85	0,87	1,03	1,17	1,32	1,38	1,42
4	0,16	0,14	0,11	0,10	0,12	0,11	0,10	0,10	0,12	0,12	0,12
5	0,45	0,22	0,44	0,47	0,50	0,57	0,80	0,94	1,10	1,13	1,16
6	0,11	0,09	0,08	0,07	0,06	0,07	0,09	0,08	0,06	0,07	0,07
7	0,35	0,19	0,36	0,51	0,57	0,58	0,75	0,83	0,91	0,96	0,99
8	0,04	0,03	0,04	0,03	0,03	0,02	0,03	0,03	0,03	0,05	0,05
9	0,13	0,32	0,18	0,32	0,37	0,41	0,54	0,61	0,69	0,69	0,71
10	0,03	0,03	0,03	0,04	0,06	0,04	0,06	0,05	0,05	0,06	0,06
11	0,19	0,27	0,18	0,29	0,36	0,38	0,50	0,54	0,59	0,61	0,61
12	0,03	0,03	0,03	0,05	0,05	0,06	0,07	0,08	0,07	0,07	0,06
13	0,07	0,10	0,16	0,18	0,23	0,26	0,35	0,39	0,42	0,43	0,45
14	0,04	0,05	0,05	0,07	0,09	0,07	0,09	0,08	0,08	0,08	0,07
15	0,09	0,11	0,17	0,15	0,19	0,20	0,28	0,32	0,36	0,37	0,37
16	0,05	0,05	0,05	0,05	0,07	0,06	0,07	0,07	0,07	0,08	0,08
17	0,03	0,09	0,12	0,08	0,10	0,10	0,18	0,22	0,26	0,29	0,30
18	0,07	0,07	0,07	0,06	0,05	0,07	0,08	0,08	0,09	0,09	0,09
19	0,03	0,04	0,08	0,04	0,06	0,06	0,15	0,19	0,22	0,25	0,27
20	0,07	0,07	0,08	0,07	0,04	0,07	0,08	0,08	0,08	0,09	0,09
21	0,06	0,05	0,05	0,03	0,04	0,04	0,11	0,14	0,18	0,20	0,21
22	0,10	0,10	0,10	0,09	0,09	0,09	0,10	0,10	0,11	0,12	0,13
23	0,06	0,06	0,06	0,03	0,02	0,04	0,09	0,12	0,16	0,18	0,18
24	0,10	0,10	0,09	0,09	0,04	0,09	0,10	0,11	0,12	0,12	0,13
25	0,07	0,07	0,07	0,04	0,04	0,03	0,06	0,09	0,10	0,13	0,13
26	0,10	0,10	0,10	0,10	0,05	0,10	0,11	0,12	0,15	0,15	0,14
27	0,07	0,08	0,06	0,04	0,03	0,03	0,05	0,07	0,09	0,10	0,12
28	0,08	0,10	0,10	0,10	0,07	0,10	0,10	0,10	0,12	0,12	0,12
29	0,05	0,06	0,04	0,05	0,04	0,03	0,04	0,05	0,06	0,08	0,10
30	0,15	0,14	0,12	0,12	0,04	0,12	0,14	0,12	0,12	0,14	0,16
31	0,05	0,05	0,04	0,05	0,03	0,03	0,04	0,04	0,06	0,08	0,09
32	0,11	0,11	0,11	0,11	0,06	0,11	0,12	0,11	0,15	0,15	0,13
33	0,05	0,05	0,04	0,04	0,03	0,04	0,04	0,04	0,05	0,06	0,08
34	0,12	0,14	0,12	0,12	0,01	0,11	0,11	0,12	0,14	0,16	0,17
35	0,06	0,06	0,05	0,05	0,04	0,04	0,04	0,04	0,05	0,06	0,07
36	0,13	0,12	0,12	0,14	0,03	0,14	0,15	0,16	0,17	0,20	0,19
37	0,05	0,06	0,05	0,04	0,03	0,03	0,04	0,04	0,05	0,05	0,06
38	0,15	0,15	0,12	0,13	0,03	0,12	0,13	0,13	0,15	0,16	0,18
39	0,05	0,05	0,05	0,05	0,03	0,04	0,04	0,04	0,05	0,05	0,06
40	0,14	0,12	0,11	0,11	0,08	0,10	0,10	0,11	0,14	0,16	0,14



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

Inter-harmonics (Solis-1P4.6K-4G)											
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100
Frequency [Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
75	0,10	0,13	0,18	0,25	0,44	0,37	0,45	0,47	0,55	0,57	0,58
125	0,03	0,05	0,07	0,11	0,20	0,16	0,19	0,20	0,25	0,25	0,25
175	0,02	0,03	0,03	0,05	0,09	0,08	0,10	0,10	0,12	0,13	0,13
225	0,02	0,01	0,02	0,03	0,07	0,05	0,07	0,08	0,09	0,10	0,10
275	0,01	0,02	0,02	0,02	0,03	0,03	0,04	0,04	0,05	0,05	0,06
325	0,01	0,02	0,01	0,03	0,06	0,05	0,06	0,06	0,08	0,08	0,08
375	0,02	0,01	0,02	0,02	0,03	0,03	0,03	0,03	0,04	0,04	0,04
425	0,01	0,01	0,01	0,01	0,03	0,03	0,04	0,04	0,05	0,05	0,05
475	0,01	0,01	0,02	0,02	0,02	0,02	0,03	0,03	0,03	0,03	0,03
525	0,01	0,01	0,01	0,01	0,02	0,02	0,03	0,04	0,05	0,05	0,05
575	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02	0,03	0,03	0,03
625	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,03	0,03	0,04	0,04
675	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02	0,02	0,03	0,03
725	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,03	0,03	0,03
775	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,03	0,02	0,03
825	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02
875	0,01	0,01	0,01	0,01	0,02	0,02	0,03	0,02	0,03	0,03	0,03
925	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02
975	0,01	0,01	0,01	0,01	0,02	0,02	0,03	0,02	0,03	0,03	0,03
1025	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,01	0,01	0,02	0,02
1075	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,03	0,03	0,03
1125	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,01	0,02	0,02
1175	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,03	0,02	0,03
1225	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02
1275	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,03	0,03
1325	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02
1375	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,03	0,03
1425	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02
1475	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,03
1525	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02
1575	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,03	0,03
1625	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02
1675	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02
1725	0,01	0,01	0,01	0,01	0,02	0,01	0,02	0,02	0,02	0,02	0,02
1775	0,01	0,01	0,01	0,01	0,02	0,01	0,02	0,02	0,02	0,02	0,03
1825	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02
1875	0,01	0,01	0,01	0,01	0,02	0,01	0,01	0,02	0,02	0,02	0,02
1925	0,01	0,01	0,01	0,01	0,02	0,01	0,02	0,02	0,02	0,02	0,02
1975	0,01	0,01	0,01	0,01	0,01	0,01	0,02	0,02	0,02	0,02	0,02



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

Higher frequencies (Solis-1P4.6K-4G)											
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100
Frequency [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2,1	0,15	0,13	0,11	0,11	0,03	0,15	0,12	0,11	0,12	0,13	0,15
2,3	0,14	0,12	0,11	0,11	0,06	0,15	0,12	0,11	0,12	0,13	0,15
2,5	0,10	0,08	0,08	0,08	0,07	0,10	0,08	0,08	0,08	0,09	0,11
2,7	0,10	0,08	0,08	0,09	0,04	0,11	0,09	0,09	0,10	0,10	0,11
2,9	0,08	0,06	0,07	0,07	0,03	0,08	0,06	0,07	0,06	0,07	0,09
3,1	0,07	0,06	0,06	0,06	0,04	0,07	0,06	0,06	0,05	0,05	0,06
3,3	0,06	0,05	0,06	0,06	0,05	0,06	0,05	0,04	0,04	0,04	0,04
3,5	0,06	0,05	0,05	0,06	0,06	0,06	0,05	0,04	0,03	0,04	0,04
3,7	0,06	0,04	0,04	0,05	0,02	0,04	0,03	0,04	0,03	0,03	0,03
3,9	0,06	0,04	0,04	0,04	0,03	0,04	0,03	0,04	0,03	0,03	0,03
4,1	0,05	0,04	0,04	0,04	0,02	0,04	0,03	0,03	0,03	0,03	0,03
4,3	0,04	0,03	0,03	0,03	0,03	0,04	0,03	0,03	0,03	0,03	0,03
4,5	0,04	0,03	0,03	0,03	0,03	0,04	0,03	0,03	0,03	0,03	0,03
4,7	0,04	0,03	0,03	0,03	0,01	0,04	0,03	0,03	0,03	0,04	0,04
4,9	0,03	0,03	0,03	0,03	0,02	0,04	0,03	0,03	0,03	0,03	0,03
5,1	0,05	0,03	0,03	0,03	0,02	0,04	0,03	0,04	0,04	0,04	0,04
5,3	0,04	0,03	0,03	0,03	0,00	0,04	0,03	0,03	0,03	0,04	0,04
5,5	0,05	0,04	0,04	0,04	0,02	0,05	0,04	0,04	0,04	0,05	0,05
5,7	0,04	0,04	0,04	0,04	0,03	0,05	0,05	0,04	0,04	0,05	0,05
5,9	0,05	0,05	0,05	0,04	0,03	0,06	0,05	0,05	0,05	0,05	0,06
6,1	0,05	0,05	0,05	0,05	0,02	0,06	0,05	0,05	0,06	0,05	0,05
6,3	0,06	0,05	0,05	0,05	0,02	0,07	0,06	0,05	0,05	0,06	0,05
6,5	0,06	0,06	0,06	0,06	0,02	0,07	0,06	0,06	0,06	0,06	0,06
6,7	0,05	0,06	0,06	0,06	0,04	0,07	0,06	0,06	0,06	0,06	0,07
6,9	0,09	0,08	0,08	0,08	0,07	0,10	0,10	0,08	0,09	0,09	0,09
7,1	0,08	0,09	0,08	0,09	0,05	0,10	0,10	0,10	0,10	0,10	0,10
7,3	0,07	0,07	0,09	0,07	0,05	0,10	0,08	0,09	0,09	0,09	0,09
7,5	0,11	0,11	0,11	0,11	0,06	0,13	0,10	0,11	0,12	0,11	0,11
7,7	0,38	0,34	0,28	0,28	0,02	0,35	0,22	0,18	0,20	0,19	0,19
7,9	0,13	0,13	0,12	0,13	0,68	0,21	0,23	0,16	0,19	0,19	0,20
8,1	0,12	0,12	0,14	0,18	0,65	0,25	0,11	0,13	0,18	0,21	0,20
8,3	0,43	0,35	0,30	0,28	0,10	0,37	0,24	0,21	0,22	0,25	0,24
8,5	0,15	0,12	0,11	0,12	0,04	0,16	0,11	0,13	0,13	0,14	0,12
8,7	0,08	0,09	0,09	0,09	0,04	0,11	0,10	0,10	0,11	0,11	0,11
8,9	0,09	0,08	0,07	0,08	0,05	0,10	0,09	0,09	0,09	0,10	0,09

Handwritten signature



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

E.6 Certificate of the network and system protection

Certificate of NS protection	No. 70.409.19.076.10-00		
Manufacturer	Ningbo Ginlong Technologies Co., Ltd. No.57 Jintong Road, Binhai Industrial Park, Xiangshan, 315712 Ningbo, Zhejiang, PEOPLE'S REPUBLIC OF CHINA		
Type of NS protection	-		
Central NS protection	☐	-	
Integrated NS protection	☒	Assigned to power generation unit type	Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G
Network connection rules	VDE-AR-N 4105 "Power generation systems connected to the low-voltage network" Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network		
Test requirement	E DIN VDE V 0124-100 (VDE V 0124-100) "Network integration of power generation system – Low voltage" Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network		
The network and system protection mentioned above meets the requirements of VDE-AR-N 4105.			

No. D 086470 0053 Rev. 00

E.7 Requirement for the test report for the NS protection

A4 / 07.17



Product Service

Compliance Document

No. D 086470 0053 Rev. 00

☒ as integrated NS protection	
Assigned to power generation unit type	Solis-1P2.5K-4G, Solis-1P3K-4G, Solis-1P3.6K-4G, Solis-1P4K-4G, Solis-1P4.6K-4G
Integrated interface switch type	Series-connected relays for both the neutral conductor and the line conductor Relay type: ALFG2PF121 or ALFG2PF12 or AZSR126-1AE-12D or AZSR131-1AE-12D
Response time of interface switch for integrated NS protection	Operate time: Max. 20 ms (ALFG2PF121 or ALFG2PF12 or AZSR126-1AE-12D or AZSR131-1AE-12D) Release time: Max. 10 ms (ALFG2PF121 or ALFG2PF12 or AZSR126-1AE-12D or AZSR131-1AE-12D)
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.	☒

**Tested
according to:**

VDE-AR-N 4105:2018
E DIN VDE V 0124-100 (VDE V 0124-100):2019