

## VERIFICATION OF COMPLIANCE

| No.: | GZES2011031268PV |
|------|------------------|
| INU  | GZE32011031200FV |

Applicant: Shenzhen Atess Power Technology Co., Ltd

1st Floor of Building 3 at Sector B and 3rd Floor of Building 9, Henglong Industrial Park, Shuitian, Baoan District, Shenzhen,

Guangdong, China

Manufacturer: Shenzhen Atess Power Technology Co., Ltd

1st Floor of Building 3 at Sector B and 3rd Floor of Building 9, Henglong Industrial Park, Shuitian, Baoan District, Shenzhen,

Guangdong, China

Product Name: Hybrid Inverter (Three Phase)
Product Description: Inverter used in PV system
Model No.: HPS100, HPS120, HPS150

**ATESS** 

Rating: Refer to page 2

Intended Use: PV System

Protection against Electric Shock: Class I Additional Information (if any): IP 20

Firmware version: DSP: HV3-SV4.1.09; LCD: HV1.0-SV1.0.4

Internal Transformer: Yes

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: ENA Engineering Recommendation G99 Issue 1 Amendment 3

2018

as shown in the

Trade Mark:

Test Report Number(s): GZES201103126801

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant specific standards.

NEW CO

Senior Technical Manager

2021-03-22

SGS-CSTC

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)



No.: GZES2011031268PV

Other information added : Ratings

| Model Number                    | HPS100                         | HPS120  | HPS150  |  |
|---------------------------------|--------------------------------|---------|---------|--|
| PV parameters                   |                                |         |         |  |
| PV rated Power                  | 110 kW                         | 132 kW  | 165 kW  |  |
| Max. PV Power                   | 150 kW                         | 180 kW  | 225 kW  |  |
| Max. PV input voltage           | 1000 Vd.c.                     |         |         |  |
| PV MPPT voltage range           | 480-800 Vd.c.                  |         |         |  |
| Battery parameters              |                                |         |         |  |
| Battery operating voltage range | 352-600 Vd.c.                  |         |         |  |
| Max.Battery charge current      | 300 A                          | 350 A   | 450 A   |  |
| Max.Battery discharge current   | 313 A                          | 374 A   | 467 A   |  |
| Max.Battery charge power        | 150 kW                         | 180 kW  | 225 kW  |  |
| Max.Battery discharge power     | 110 kW                         | 132 kW  | 165 kW  |  |
| AC output parameter             |                                |         |         |  |
| Rated voltage                   | 400 Vac                        |         |         |  |
| Rated current                   | 144 A                          | 173 A   | 217 A   |  |
| Rated output power              | 100 kW                         | 120 kW  | 150 kW  |  |
| Rated frequency                 | 50 Hz                          |         |         |  |
| Frequency Range                 | 45-55 Hz                       |         |         |  |
| Max.output power                | 110 kVA                        | 132 kVA | 165 kVA |  |
| Max. input power                | 200 kVA                        | 240 kVA | 240 kVA |  |
| Power factor                    | 1 default (+/- 0.8 adjustable) |         |         |  |
| Ambient temperature             | -25 °C ~ 55 °C                 |         |         |  |
| Ingress protection              | IP20                           |         |         |  |
| Protective class                | Class I                        |         |         |  |

David Guo Senior Technical Manager

2021-03-22

SGS-CSTC

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.