

TEST REPORT

Engineering Recommendation G99

Issue 1 – Amendment 9

Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019

Shenzhen Atess Power Technology Co., Ltd

For the unit(s) **HF**

HPS30, HPS50

Test report no.

HC23072104-EG-UK-001

Date 2023-08-21



LYNS-TC:

Test report number:	HC23072104-EG-U	IK-001		
Date of issue	2023-08-21			
Total number of pages	56			
Testing laboratory:	Lyns-tci Technology Guangdong Co., Ltd.			
Address:	1201, Unit 2, Building 18, No. 7, Science and Technology Boulevard, Houjie Town, Dongguan City, Guangdong, 523960			
Testing location / address	Same as above			
Applicant's name:	Shenzhen Atess P	ower Technology Co., Ltd		
Address:	2nd Floor, No.23 Zhulongtian Road, Shuitian Community, Shiyar Street, Baoan District, Shenzhen, China			
Test specification				
Standard:	 Engineering Recommendation G99 Issue 1 – Amendment 9 3 October 2022 Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019 			
Test report form number:	EREC G99_v1.0			
Test report form(s) originator:	Lyns-tci Technology	y Guangdong Co., Ltd.		
Master TRF:	Dated 2022-02-01			
Test item description:	Device Category:	Inverter		
	Device Type: Hybrid Inverter (PV + DC coupled Electricity Storage)			
Trademark:	ATESS			
Model / Type reference:	HPS30, HPS50			
Technical data	: See section 3.1 on p.8			
Dates of testing	2023-08-01 - 2023-08-19			

Tested / Report prepared by

Allen

Allen Zhang (Test engineer)

Approved by

Lukes Lin (Project manager)

Contents

1	Ger	neral information of test report	5
	1.1	Important Note	5
	1.2	Revision history	5
2	Ger	neral remarks for documentation	6
3	Ger	neral product information	8
	3.1	Technical data of the unit(s)	8
	3.2	Description of the differences of the models within the product series	11
	3.3	Copy of marking plate	12
	3.4	Description of the power circuit	14
4	Ger	neral remarks for testing	15
	4.1	PGM categories	15
	4.2	Energy Conversion Technology	15
	4.3	Exceptions	16
	4.4	Scope of measurements	17
	4.5	Reference values	19
	4.6	Measurement setup	19
	4.7	Measurement equipment	21
5	Ass	sessment overview	22
6	Me	easurement results	24
	6.1	Operating Range	24
	6.2	Power Quality – Harmonics	26
	6.3	Power Quality – Voltage fluctuations and Flicker	29
	6.4	Power Quality – DC injection	30
	6.5	Power Factor	31
	6.6	Protection	31
	6.6	5.1 Protection – Frequency tests	32
	6.6	5.2 Protection – Voltage tests	34
	6.6	5.3 Protection – Loss of Mains test	39
	6.6	5.4 Loss of Mains Protection, Vector Shift Stability test	39
	6.6	5.5 Loss of Mains Protection, RoCoF Stability test	41
	6.7	Limited Frequency Sensitive Mode – Overfrequency test	42
	6.8	Protection – Re-connection timer	44
	6.9	Fault level contribution	44
	6.10	Self-Monitoring solid state switching	44
	6.11	Wiring functional tests	45

6.12	Logic interface (input port)	45
6.13	Cyber security	.45
Annex 1	- Loss of Mains test according to BS EN 62116	.47
Annex 2	- Manufacturer's declaration regarding Cyber Security	.48
Annex 3	- CE declaration	.50
Annex 4	- ISO 9001 certificate	51
Annex 5	- Photo of the unit	.52

1 General information of test report

1.1 Important Note

General disclaimer

The test results presented in this report relate only to the object tested.

This report is for the exclusive use of LYNS's Client and is provided pursuant to the agreement between LYNS and its Client. This report shall not be reproduced, except in full, without the written approval of LYNS. Test reports without seal and signature are not valid.

LYNS 's responsibility and liability are limited to the terms and conditions of the agreement. LYNS assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned using this report.

Information on derived or extended models of the range as provided by the applicant (if any) is included in this report for information purposes only. LYNS shall not be liable for any incorrect results due to unclear, incorrect, incomplete, misleading or false information provided by client.

1.2 Revision history

Report version	Date	Editor	Modification / Change	Status
HC23072104-EG- UK-001	2023-08-21	Allen Zhang	Initial report was written	Active

2 General remarks for documentation

The test results presented in this report relate only to the object(s) tested.

Throughout this report a \Box comma ',' / \boxtimes point '.' is used as decimal separator and a \Box point '.' / \boxtimes comma ',' as thousands separator.

The following suffixes/indices are used for variables in tables and figures:

n	Nominal value
max	Maximum value
Lx	index of phase x
LxLy	phase-to-phase voltages of phase x and phase y

Abbreviations

AC **Alternating Current** 1 DC ÷ **Direct Current** EUT : Equipment Under Test LV Low Voltage ÷ MP : **Measurement Point** MPP Maximum Power Point 2 ΜV Medium Voltage ÷ PGF : **Power Generating Facility** PGM : **Power Generating Module** PGU **Power Generating Unit** ÷ P_{max} ÷ **Registered Capacity** PPM 1 **Power Park Module** PWHD : Partial Weighted Harmonic Distortion THD : **Total Harmonic Distortion** PWHD : Partial Weighted Harmonic Distortion

Direction definition of P and Q

in this test report, the regarded system of the voltage and current vectors is the active sign convention system:

- If the inverter feeds to the grid the active power is measured with positive sign.
- If the inverter injects reactive power / current with leading power factor the reactive power / current is marked "leading" or "inductive" (under-excited) or has a negative sign.
- If the inverter injects reactive power / current with lagging power factor the reactive power / current is marked "lagging" or "capacitive" (over-excited) or has a positive sign.



3 General product information

Factory's name Shenzhen Atess Power Technology Co., Ltd.

Factory address: 2nd Floor, No.23 Zhulongtian Road, Shuitian Community, Shiyan Street, Baoan District, Shenzhen, China

3.1 Technical data of the unit(s)

Unit / Type:	HPS30	HPS50	
Hardware version (tested):	e version (tested) SSCP HW V1.1.1		
Software version (tested):	HPS30K 150K H	V3 SV4.1.14 APP	
DC input (PV)			
Max. DC input voltage [V]:	10	00	
Operating MPPT voltage range [V]:	480 -	~ 800	
Input DC current [A]:	max. 90	max. 136	
Battery connection			
Battery voltage range [V] : 352 ~ 600			
Battery charging current [A]:	max. 100	max. 150	
Battery discharging current [A]:	max. 93	max. 156	
Battery charging power [kW]:	45.0	75.0	
Battery discharging power [kW]:	33.0	55.0	
AC connection			
Nominal output AC voltage [V]:	230/400 (3~ + N	+ PE, 50/60 Hz)	
Output AC current [A]:	max. 47.0	max. 79.0	
Nominal active output power Pn [kW] :	30.0	50.0	
Registered Capacity ¹ P _{max} [kW]	30.0	50.0	
Max. apparent power [kVA]	33.0	55.0	

Note:

The Power Park Modules (Generating Units) considered in this report are designed to be capable of operating within the range ± 0.95 Power Factor at Registered Capacity.

- Max. operating range of Power Factor at Registered Capacity: 0.909 lagging to 0.909 leading
- Setting range of the Power Factor: 0.800 lagging to 0.800 leading

¹ In this report, the stated values of "registered capacity" related to single Generating Unit.

Datasheet of the generating units:

Note:

the units HPS100, HPS120 and HPS150 are not considered in this test report.

Model	HPS30		
	PV parameter		
PV rated power	33KW		
Max. PV power	45KW		
Max. PV open circuit voltage	1000V		
PV MPPT voltage range	480Vdc-800Vdc		
Max.PV input current	90A		
	Battery parameter		
Battery operating voltage range	352V-600V		
Max battery charge current	100A		
Max battery discharge current	93A		
Max battery charge power	45KW		
Max battery discharge power	33kw		
	AC output parameter		
Rated voltage	400Vac		
Rated current	43A		
Rated power	30KW		
Rated frequency	50/60Hz		
Frequency Range	45-55Hz/55-65Hz		
Max. AC output power	33KVA		
Max. AC input power	60KVA		
Power factor	0.8lagging—0.8leading		
THDI	<3%(Full load)		
THDU	≤2%		
Overload capacity	110%-10 mins,120%-1 min		
	Other parameter		
Ingress Protection	IP20(Outdoors)		
Protective class	Class I		
Mains over voltage category	OVC III		
PV over voltage category	OVC II		
Demand response mode	DRM0-8 (optional)		
Inverter toplogy	Isolated		
Noise emission	<65dB (A) @1m		
Cooling	Intelligent air cooling		
Humidity	0%-95% non-condensing		
Maximum altitude	6000 (derate over 3000m)		
Build-in transformer	yes		
Operating temperature	-25°C-+55°C		
Active anti-islanding method	nethod Shifting the frequency of the inverter away from nominal conditions in the absence of a reference frequency (frequency shift)		
	Communication		
LCD display	Touch screen LCD		
Communication interface	RS485/CAN		

ModelHPS100HPS120HPS120HPS120HPS120HPS120PV parameterPV parameterS5KW110KW132KW165KWMax. PV open circuit voltage1000V1000V1000V1000VMax. PV open circuit voltage1000V1000V1000V1000VMax. PV input current136A230A327A409ABattery operating voltage range352V-600VMax battery charge current150A300A350A450AMax battery charge current156A313A374A467AMax battery charge power75KW150KW180KW225KWMax battery discharge power75KW150KW180KW225KWMax battery discharge power55Kw110KW132LW165KwAcc output parameterRated voltage400VacRated voltage400Vac120KW150KWRated requency50K0W100KW120KW150KWRated power55KVA110KVA132KVA165KVAMax. AC output power55KVA110KVA240KVA240KVAPower factor0.8lagging0.8leading110K-10THDI<3%(Full load)110K-10110K-10IntroductorsProtective classClass1Mains over voltage categoryOVC IIIPV over voltage categoryOVC IIIPV over voltage category			1100100	1100100	1100450	
PV parameter PV rated power 55KW 110KW 132KW 165KW Max. PV open circuit voltage 1000V 1000V 1000V 1000V PV MPT voltage range 480Vdc-800Vdc Max.PV input current 136A 230A 327A 409A Battery operating voltage range 352V-600V Max battery charge current 136A 313A 374A 467A Max battery charge current 156A 313A 374A 467A Max battery discharge power 75KW 150KW 180KW 225KW Max battery discharge power 75KW 150KW 180KW 225KW Max battery discharge power 75KW 110KW 132kW 165kw AC output parameter Rated voltage 400Vac Rated requency 50KW 100KW 120KW 150KW Rated frequency 50KW 100KW 120KW 150KW 8ated frequency 50KW 100KW 132KW 150KW 8ated frequency 50KW 100KW 132KW 150KW 100KW 120KW 150KW 8ated frequency 50KW 100KW 132KVA 165KVA Max. AC output power 55KVA 110KVA 132KVA 165KVA Max. AC output power 55KVA 110KVA 132KVA 165KVA Max. AC output power 55KVA 110KVA 200KVA 200KVA 240KVA 240KVA 200KVA 240KVA 240KVA 200KVA 240KVA 240KVA 240KVA 200KVA 240KVA 240KVA 200KVA 240KVA 200KVA 240KVA Power factor 00KP 110%-10 mins, 120%-1 min 0ther parameter Ingress Protection PV over voltage category 0VC II PV over voltage category 0VC II PV over voltage category 0VC II Demand response mode DRM0-8 (optional) Inverter toplogy Isolated Noise emission <563B A @1m Cooling Intelligent air cooling Humidity 0%-95% non-condensing Maximum altitude 6000 (derate over 3000m) Build-in transformer Ves Operating temperature -25 -+55 Active anti-islanding method Shifting the frequency of the inverter away from nominal conditions in the absence of a reference frequency (frequency shift) Communication interface 85485/CAN	Model	HPS50	HPS100	HPS120	HPS150	
TV nate power 55KW 110KW 132KW 125KW Max. PV pen circuit voltage 1000V 1000V 1000V 1000V PV MPPT voltage range 480Vdc-800Vdc 1000V 1000V Max. PV input current 136A 230A 327A 409A Battery parameter 352V-600V 480Vdc-800Vdc 400A Max battery charge current 150A 300A 350A 450A Max battery charge current 156A 313A 374A 467A Max battery discharge current 156A 313A 374A 467A Max battery discharge power 75KW 150KW 180KW 225KW Max battery discharge power 75KW 110KW 132kW 165kw Rated voltage 400Vac 400Vac 8ated power 50KW 100KW 120KW 150KW Rated power 50KW 100KW 120KW 150KW 165kVA Max. AC input power 50KW 100KVA 240KVA 240KVA Power factor 0.81agging—0.81eading 110KIA 132kVA 165kVA	DV rated actives	PV parameter				
Max. PV power75KW150KW180KW225KWMax. PV open circuit voltage1000V1000V1000V1000VMax. PV input current136A230A327A409ABattery operating voltage range352V-600V350A450AMax battery charge current156A313A374A467AMax battery charge current156A313A374A467AMax battery charge power75KW150KW180KW225KWMax battery charge power75KW150KW180KW225KWMax battery discharge power75KW110kW132kw165kwRated voltage400Vac400Vac88Rated voltage400Vac400Vac8100KW120KWRated power50KW100KW120KW150KW165KVARated power50KW100KW120KW165KVA165KVAMax. AC output power55KVA110KVA140KVA240KVAPower factor0.8lagging-0.8leading1100<3%(Full load)	PV rated power	55KW	110KW	132KW	165KW	
Max. PV open circuit voltage 1000V 1000V 1000V PV MPPT voltage range 480Vdc-800Vdc Max.PV input current 136A 230A 327A 409A Battery operating voltage range 352V-600V 400A Max battery charge current 150A 300A 350A 450A Max battery charge current 156A 313A 374A 467A Max battery discharge current 156A 313A 374A 467A Max battery discharge power 75KW 150KW 180KW 225KW Max battery discharge power 55kw 110kw 132kw 165kw Rated voltage 400Vac 400Vac Rated current 72A 144A 173A 217A Rated power 50KW 100KW 120KW 150KW 180KW 225KW Max. AC output power 50KW 100KVA 120KVA 240KVA Power factor 0.8lagging—0.8laging—0.8laging 0.8lagging—0.8laging THDI <3%(Full load)	Max. PV power	75KW	150KW	180KW	225KW	
PV MPPT voltage range 480Vdc-800Vdc Max.PV input current 136A 230A 327A 409A Battery parameter 352V-600V Max battery charge current 150A 300A 350A 450A Max battery discharge current 156A 313A 374A 467A Max battery discharge power 75KW 150KW 180KW 225KW Max battery discharge power 75KW 150KW 180KW 225KW Max battery discharge power 75KW 150KW 180KW 225KW Max battery discharge power 75KW 110kw 132kw 165kw Rated voltage 400Vac 400Vac 420KW 100KW 120KW 150KW Rated power 50KW 100KW 120KW 165KVA Max. AC output power 55KVA 110KVA 132kVA 240KVA Max. AC output power 55KVA 110KVA 132kVA 240KVA 240KVA Power factor 0.8lagging—0.8lagging 0.8lagging—0.8laging 0.8lagging	Max. PV open circuit voltage	1000V	1000V	1000V	1000V	
Max. PV input current136A230A327A409ABattery operating voltage rangeBattery operating voltage rangeBattery operating voltage range352V-600VMax battery charge current150A300A350A450AMax battery charge current156A313A374A467AMax battery charge power75KW150KW180KW225KWMax battery discharge power75KW110kw132kw165kwAc output parameterAC output parameter8ated voltage400VacRated voltage400Vac120KW150KW150KWRated power50/60Hz50/60Hz150KW150KWFrequency Range45-55Hz/565Hz100KVA240KVA240KVAPower factor0.8lagging—0.8leading165KVA108KVA240KVAPower factor0.8lagging—0.8leading110%-10 mins,120%-1 min170KVATHDI<\$2%	PV MPPT voltage range		480Vdc	-800Vdc		
Battery parameterBattery operating voltage range352V-600VMax battery charge current150A300A350A450AMax battery discharge current156A313A374A467AMax battery discharge power75KW150KW180KW225KWMax battery discharge power55kw110kw132kw165kwAc output parameter400Vac8165kw100KW120KWRated voltage400Vac400Vac150KW150KW150KWRated power50KW100KW120KW150KW150KWRated frequency50/60Hz50KOHz150KW165KVAMax. AC output power55KVA110KVA132KVA165KVAMax. AC output power55KVA110KVA240KVA240KVAPower factor0.8lagging—0.8laeding1HDI<3%(Full load)	Max.PV input current	136A	230A	327A	409A	
Battery operating voltage range352V-600VMax battery charge current150A300A350A450AMax battery discharge current156A313A374A467AMax battery discharge power75KW150KW180KW225KWMax battery discharge power55kw110kw132kw165kwRated voltage400Vac8400Vac8400Vac8400VacRated current72A144A173A217ARated gower50KW100KW120KW150KWRated frequency50/60Hz50/60Hz100KVA120KWFrequency Range45-55Hz/55-65HzMax. AC output power55KVA110KVA132KVA165KVAMax. AC output power50KVA110KVA132KVA240KVA240KVA240KVA240KVAPower factor0.8lagging—0.8leading1100<3%(Full load)		Battery pa	rameter			
Max battery charge current150A300A350A450AMax battery discharge current156A313A374A467AMax battery discharge power75KW110kW132kW165kwMax battery discharge power55kw110kw132kw165kwRated voltage400Vac400Vac84ed current72A144A173A217ARated power50KW100KW120KW150KW150KW150KWRated frequency50/60Hz50/60Hz50/60Hz50/60HzFrequency Range45-55Hz/55-65Hz100KVA240KVA240KVAPower factor0.8lagging-0.8laeding110K-10 mins,120%-1 min165KVAMax. AC input power100KVA200KVA240KVA240KVAPower factor0.8lagging-0.8laeding110W-10 mins,120%-1 minTHDI<3%(Full load)	Battery operating voltage range		352\	V-600V		
Max battery discharge current156A313A374A467AMax battery charge power75KW150KW180KW225KWMax battery discharge power55kw110kw132kw165kwAC output parameterRated voltage400VacRated current72A144A173A217ARated frequency50KW100KW120KW150KWRated frequency50KW100KVA120KW150KWRated frequency Range45-55Hz/55-65HzMax. AC output power55KVA110KVA132KVA165KVAMax. AC output power55KVA110KVA132KVA240KVA240KVA240KVAPower factor0.8lagging—0.8leading1HDI<3%(Full load)	Max battery charge current	150A	300A	350A	450A	
Max battery charge power75 KW150 KW180 KW225 KWMax battery discharge power55 kw110 kw132 kw165 kwAC output parameterRated voltage400 VacRated current72 A144 A173 A217 ARated power50 KW100 KW120 KW150 KWRated frequency50 / 60 HzFrequency Range45 - 55 Hz / 55 - 65 HzMax. AC output power55 KVA110 KVA132 KVA165 KVAPower factor0.8 lagging—0.8 leadingTHDI<3% (Full load)	Max battery discharge current	156A	313A	374A	467A	
Max battery discharge power55kw110kw132kw165kwAC output parameterRated voltage400VacRated current72A144A173A217ARated power50KW100KW120KW150KWRated frequency50/60Hz50/60HzFrequency Range45-55Hz/55-65Hz165KVAMax. AC output power55KVA110KVA132KVA165KVAPower factor0.8lagging—0.8leading14DU240KVA240KVAPower factor0.8lagging—0.8leading11DW-10 mins, 120%-1 minTHDI<\$2%	Max battery charge power	75KW	150KW	180KW	225KW	
Rated voltage 400Vac Rated current 72A 144A 173A 217A Rated power 50KW 100KW 120KW 150KW Rated frequency 50/60Hz 50/60Hz Frequency Range 45-55Hz/55-65Hz Max. AC output power 55KVA 110KVA 132KVA 165KVA Max. AC output power 0.81agging—0.81aeding 240KVA 240KVA 240KVA Power factor 0.81agging—0.81aeding THDI <3%(Full load)	Max battery discharge power	55kw	110kw	132kw	165kw	
Rated voltage400VacRated current72A144A173A217ARated current72A144A173A217ARated power50KW100KW120KW150KWRated frequency50/60Hz55KZA55Hz/S5-65HzMax. AC output power55KVA110KVA132KVA165KVAMax. AC output power100KVA200KVA240KVA240KVAPower factor0.8lagging—0.8leading110k-10 mins, 120%-1110k-10 mins, 120%-1THDI<3%(Full load)		AC output p	arameter			
Rated current72A144A173A217ARated power50KW100KW120KW150KWRated frequency50/60HzFrequency Range45-55Hz/55-65HzMax. AC output power55KVA110KVA132KVA165KVAMax. AC input power100KVA200KVA240KVA240KVAPower factor0.8lagging—0.8leading1HDI<3%(Full load)	Rated voltage		400	OVac		
Rated power50KW100KW120KW150KWRated frequency50/60HzFrequency Range45-55Hz/55-65HzMax. AC output power55KVA110KVA132KVA165KVAMax. AC input power100KVA200KVA240KVA240KVAPower factor0.8lagging—0.8leading110ad)THDI<3%(Full load)	Rated current	72A	144A	173A	217A	
Rated frequency 50/60Hz Frequency Range 45-55Hz/55-65Hz Max. AC output power 55KVA 110KVA 132KVA 165KVA Max. AC input power 100KVA 200KVA 240KVA 240KVA Power factor 0.8lagging—0.8leading 240KVA 240KVA Power factor 0.8lagging—0.8leading 0.8leading THDI <3%(Full load)	Rated power	50KW	100KW	120KW	150KW	
Frequency Range45-55Hz/55-65HzMax. AC output power55KVA110KVA132KVA165KVAMax. AC input power100KVA200KVA240KVA240KVAPower factor0.8lagging—0.8leading110KVA240KVAPower factor0.8lagging—0.8leading110KVA240KVATHDI<3%(Full load)	Rated frequency	50/60Hz				
Max. AC output power55KVA110KVA132KVA165KVAMax. AC input power100KVA200KVA240KVA240KVAPower factor0.8lagging—0.8leading240KVA240KVAPower factor0.8lagging—0.8leading3%(Full load)THDI<\$2%	Frequency Range		45-55H	z/55-65Hz		
Max. AC input power100KVA200KVA240KVA240KVAPower factor0.8lagging—0.8leadingTHDI<3%(Full load)	Max. AC output power	55KVA	110KVA	132KVA	165KVA	
Power factor 0.8lagging0.8leading THDI <3%(Full load)	Max. AC input power	100KVA	200KVA	240KVA	240KVA	
THDI <3%(Full load)	Power factor	0.8lagging—0.8leading				
THDU ≤2% Overload capacity 110%-10 mins, 120%-1 min Other parameter Ingress Protection Ingress Protection IP20(Outdoors) Protective class Class I Mains over voltage category OVC III PV over voltage category OVC II Demand response mode DRM0-8 (optional) Inverter toplogy Isolated Noise emission <65dB A @1m	THDI	<3%(Full load)				
Overload capacity 110%-10 mins,120%-1 min Other parameter Ingress Protection IP20(Outdoors) Protective class Class I Mains over voltage category OVC III PV over voltage category OVC II Demand response mode DRM0-8 (optional) Inverter toplogy Isolated Noise emission <65dB A @1m	THDU	≤2%				
Other parameter Ingress Protection IP20(Outdoors) Protective class Class I Mains over voltage category OVC III PV over voltage category OVC II Demand response mode DRM0-8 (optional) Inverter toplogy Isolated Noise emission <65dB A @1m	Overload capacity		110%-10 mir	ns,120%-1 min		
Ingress Protection IP20(Outdoors) Protective class Class I Mains over voltage category OVC III PV over voltage category OVC II Demand response mode DRM0-8 (optional) Inverter toplogy Isolated Noise emission <65dB A @1m		Otherpar	ameter			
Protective class Class I Mains over voltage category OVC III PV over voltage category OVC II Demand response mode DRM0-8 (optional) Inverter toplogy Isolated Noise emission <65dB A @1m	Ingress Protection	IP20(Outdoors)				
Mains over voltage category OVC III PV over voltage category OVC II Demand response mode DRM0-8 (optional) Inverter toplogy Isolated Noise emission <65dB A @1m	Protective class	Classi				
PV over voltage category OVC II Demand response mode DRM0-8 (optional) Inverter toplogy Isolated Noise emission <65dB A @1m	Mains over voltage category		OVC III			
Demand response mode DRM0-8 (optional) Inverter toplogy Isolated Noise emission <65dB A @1m	PV over voltage category		0\	/CII		
Inverter toplogy Isolated Noise emission <65dB	Demand response mode		DRM0-8 (optional)		
Noise emission <65dB A @1m	Inverter toplogy		Isol	ated		
Cooling Intelligent air cooling Humidity 0%-95% non-condensing Maximum altitude 6000 (derate over 3000m) Build-in transformer yes Operating temperature -25 -+55 Active anti-islanding method Shifting the frequency of the inverter away from nominal conditions in the absence of a reference frequency (frequency shift) LCD display Communication Communication interface RS485/CAN	Noise emission		<65dB	A @1m		
Humidity 0%-95% non-condensing Maximum altitude 6000 (derate over 3000m) Build-in transformer yes Operating temperature -25 -+55 Active anti-islanding method Shifting the frequency of the inverter away from nominal conditions in the absence of a reference frequency (frequency shift) LCD display Touch screen LCD Communication interface RS485/CAN	Cooling		Intelligent	t air cooling		
Maximum altitude 6000 (derate over 3000m) Build-in transformer yes Operating temperature -25 -+55 Active anti-islanding method Shifting the frequency of the inverter away from nominal conditions in the absence of a reference frequency (frequency shift) LCD display Communication Communication interface RS485/CAN	Humidity		0%-95% no	n-condensing		
Build-in transformer yes Operating temperature -25 -+55 Active anti-islanding method Shifting the frequency of the inverter away from nominal conditions in the absence of a reference frequency (frequency shift) Communication LCD display Touch screen LCD Communication interface RS485/CAN	Maximum altitude	6000 (derate over 3000m)				
Operating temperature -25 +55 Active anti-islanding method Shifting the frequency of the inverter away from nominal conditions in the absence of a reference frequency (frequency shift) Communication Communication LCD display Touch screen LCD Communication interface RS485/CAN	Build-in transformer	yes				
Active anti-islanding method Shifting the frequency of the inverter away from nominal conditions in the absence of a reference frequency (frequency shift) Communication LCD display Touch screen LCD Communication interface RS485/CAN	Operating temperature	-25 -+55				
Communication LCD display Communication interface RS485/CAN	Active anti-islanding method	Shifting the frequency of the inverter away from nominal conditions in the absence of a reference frequency (frequency shift)				
LCD display Touch screen LCD Communication interface RS485/CAN	Communication					
Communication interface RS485/CAN	LCD display		Touch so	reen LCD		
	Communication interface	R\$485/CAN				

Equipment mobility:	Permanent connection
Operating condition::	Continuous
Class of equipment: :	Class I
Protection against ingress of water :	IP20 according to EN 60529
Mass of equipment [kg]:	HPS30: 420kg HPS50: 620kg
Type of internal transformer:	Internal transformer (transformerless)

3.2 Description of the differences of the models within the product series

The units in the product series:

- sharing the same control electronics,
- with the same firmware,
- with the same construction solutions including the power part,
- with the same number of phases,

• with the filters and build-in transformers (at the AC output of the inverter) designed for different sizes of power / current ratings.

LYNS-TC:

3.3 Copy of marking plate

ATESS Hybrid Power Systems				
Model			HPS30	
PV Max. gen Max. PV ope PV MPPT vo PV Max. inp	45kW 1000V d.c. 480-800V d.c. 90A d.c			
Isc PV		-	100A d.c.	
Battery volta Battery Max. Battery Max. Battery type	ge range charge/di charge/di	scharge current scharge power Lithium iron	100/93A d.c. 45kW/33kW phosphate battery	
Rated AC vo Rated AC fre Max. AC out Rated AC ou Max. AC out Max. AC inpu Max. AC inpu PF range Protective c Overvoltage	Rated AC voltage400V a.c.(3/N/PERated AC frequency50/60HzMax. AC output continuous current47A a.cRated AC output power30kWMax. AC output apparent power33kVAMax. AC input power60kVAMax. AC input continuous current86A a.cPF range0.8lagging0.8leadingProtective classClass			
Ingress protectionIP20Communication portRS485/CAIInverter topologyIsolatedOperating Temp.range-25°C to +55°C			IP20 RS485/CAN Isolated -25°C to +55°C	
DATE OF MADE				
S/N:		940.ZT0000)105	

ATESS Hybrid Power Systems				
Model			HI	PS50
PV Max.gene	erating pow	er		75kW
Max. PV oper	-circuit vol	tage	100	0V d.c.
PV MPPT vol	tage range		480-80	0V d.c.
PV Max. inpu	t current		13	6A d.c.
Isc PV			170.	5A d.c.
Battery voltag	je range		352-60	0V d.c.
Battery Max.	charge/disc	charge current	150/15	6A d.c.
Battery Max.	charge/disc	charge power	75kW	//55kW
Battery type		Lithium iror	n phosphat	e battery
Rated AC vol	tage	400)V a.c.(3	/N/PE)
Rated AC free	quency		5	0/60Hz
Max. AC out	out contin	uous current	7	'9A a.c.
Rated AC out	put power			50kW
Max. AC outp	out appare	nt power		55kVA
Max. AC inpu	it power		1	100kVA
Max. AC inpu	t continuo	ous current	14	4A a.c.
PF range		0.8lagg	ing0.8	leading
Protective cl	ass		C	Class I
Overvoltage	category		PV:II	AC:III
Ingress prote	ction			IP20
Communication	on port		RS48	35/CAN
Inverter top	ology		ls	olated
Operating Temp.range -25℃ to +55℃				
DATE OF MADE				
S/N: 940.ZT0000203				

Note:

The marking plates shown above may be only a draft. The use of certification marks on products must be approved by the respective NCBs to which these marks belong.

The marking plate is attached to the side surface or the back of the enclosure and is visible after installation.

3.4 Description of the power circuit

The Hybrid inverter input voltage supply can be supplied DC voltage by PV array or Battery, and the output can connect to the grid, load.

The units are three-phase.

The input and output are protected by SPDs (MOVs) to Earth. The unit is providing EMI filtering at the PV input and output toward mains.

The internal control is redundant built. It consists of Master DSP (U33) and slave DSP (33).

The master DSP which can control the relays by switching signals; measures the voltage, frequency ,and AC current.

The slave DSP is user for detecting grid voltage, grid frequency and residual current, also can open the relay, and communicate with Main DSP each other.

The unit provides two relays in series on each phase. When single fault applied to one relay, an error code will appear on display panel, another redundant relay provides basic insulation maintained between the PV array and the mains. All the relays are tested before starting up. Both DSPs can open the relays.



Figure 1 – Block diagram of the power circuit

4 General remarks for testing

4.1 PGM categories

According to definition of the standard the PGUs considered in this test report are Type A generating units:

Туре А	Туре В Туре С		Туре D
Voltag	Voltage level at connection point ≥110kV		
$0.8 \text{ kW} \le P_{\text{max}} < 1 \text{ MW}$ $1 \text{ MW} \le P_{\text{max}} < 10 \text{ MW}$ $10 \text{ MW} \le P_{\text{max}} < 50 \text{ MW}$		P _{max} ≥ 50 MW	
\square			

4.2 Energy Conversion Technology

Domestic CHP	Photovoltaic	Fuel Cells	Hydro	Wind	Electricity Storage
(1)	(2) *	(3)	(4)	(5)	devices (6)
	\boxtimes				\boxtimes

Type testing was carried out according to EREC G99, Annex A.7.

The following Additional Technology Requirements according to (depending on the selection in the table above): (1) A.7.3.1.

(2) A.7.3.2.

(3) A.7.3.3.

(4) A.7.3.4.

(5) A.7.3.5.

(6) A.7.3.6.

have been taken into account.

Measurement results documented according to EREC G99, Form A2-3.

Note:

* Connection scenario:

Dependence of the DNO's Distribution Network via an Inverter

Hybrid converter:

Photovoltaic Power Park Module with DC coupled storage unit connected to the DNO's Distribution Network via an Inverter

In this case the Registered Capacity is based on the Inverter rating. The storage unit has no compliance effect, compliance based on the inverter.

The Electricity Storage exceptions according to EREC G99, section A.4.2 do not apply to the Inverter.

LYNS-TC:

4.3 Exceptions

According to EREC G99, Annex A.4:

Emerging Technology

the following sections of EREC G99 do not apply:

- 11.2.1 (frequency withstand capability)
- 11.2.2 (rate of change of frequency)
- 11.2.3 (constant Active Power output)
- 11.2.4 (Limited Frequency Sensitive Mode Overfrequency)
- 10.6.7 (Interface Protection settings).
- □ Electricity Storage devices commissioned before 01 September 2022
 - the following sections of EREC G99 do not apply:
 - Type A less than 1 MW
 - 11.2.3 (constant Active Power output)
 - 11.2.4 (Limited Frequency Sensitive Mode Over frequency)
 - Type B 1 MW or greater but less than 10 MW
 - o 12.2.3 (constant Active Power output)
 - 12.2.4 (Limited Frequency Sensitive Mode Over frequency)
 - 12.3.1 12.3.1.7 inclusive, 12.3.4 and 12.6 (Fault Ride Through, Fast Fault Current injection)
 - Type C and Type D 10 MW or greater and / or with a Connection Point at greater than 110 kV
 - o 13.2.3 (constant Active Power output)
 - o 13.2.4 (Limited Frequency Sensitive Mode Over frequency)
 - 13.2.5 (Limited Frequency Sensitive Mode Under frequency)
 - 13.2.6 (Frequency Sensitive Mode)
 - $\circ~$ 13.3 13.3.1.11 inclusive, 13.3.4 and 13.6 (Fault Ride Through, Fast Fault Current injection)

□ Infrequent Short-Term Parallel Operation

the following sections of EREC G99 do not apply:

- Type A less than 1 MW
 - All of Section 11
- Type B 1 MW or greater but less than 10 MW
 - All of Section 12
- Type C and Type D 10 MW or greater and / or with a Connection Point at greater than 110 kV
 - All of Section 13

⊠ Other

No exceptions.

4.4 Scope of measurements

Date of receipt of test items.....: 2023-08-01 Date(s) of performance of tests.....: 2023-08-01 - 2023-08-19

During the test period stated above following environmental data were recorded:

- Temperature: 20.3 ~ 25.2°C
- Rel. humidity: 36.5 ~ 57.3%RH
- Air pressure: 985.2 ~ 1003.6 hPa

Test items	Testing requirements (Section EREC G99)	Section in this test report	Tests completed
1. Operating Range	10.3.4, 11.2.1	6.1	\boxtimes
2. Harmonics	A.7.1.4.1	6.2	\boxtimes
3. Voltage Fluctuation and Flicker	A.7.1.4.3	6.3	\boxtimes
4. DC injection	A.7.1.4.4	6.4	
5. Power Factor (PF)	A.7.1.4.2	6.5	\boxtimes
6. Frequency protection trip and ride through tests	A.7.1.2.1, A.7.1.2.3	6.6.1	
7. Voltage protection trip and ride through tests	A.7.1.2.1, A.7.1.2.2	6.6.2	
8. Protection – Loss of Mains Test, Vector Shift and RoCoF Stability Test	A.7.1.2.4, A.7.1.2.6	6.6.3, 6.6.4 and 6.6.5	
9. LFSM-O Test	A.7.1.3	6.7	\boxtimes
10. Protection – Reconnection Timer	A.7.1.2.5	6.8	
11. Fault Level Contribution	A.7.1.5	6.9	\boxtimes
12. Self-monitoring Solid State Switch	A.7.1.6	6.10	
13. Wiring functional tests if required by para 15.2.1 (attach relevant schedule of tests)	15.2.1	6.11	
14. Logic Interface (input port)	11.1.3	6.12	\boxtimes
15. Cyber security	9.1.7	6.13	2
Output power with falling frequency	11.2.3	Test not performed and not documented in this report.	

² Manufacturer's declaration provided, for details see section 6.13.

Note:

- The tests were performed on EUT HPS50 which provides the highest current / power.
- The product was tested on:
 - Serial No.: TPC0C270BD
 - Hardware Version: SSCP HW V1.1.1
 - Software Version: HPS30K 150K HV3 SV4.1.14 APP

ATES:	S					2023-8-21 13:51:17
		Manufacturer Serial Number	Shenzhen	Atess Power Techn TPC0C270BD	ology Co.,Ltd	
Time setting		DSP Software Version	HPS30_150K	WEINVIEWScreer	.1.14_APP HV1.0_SV1.1.8	
Information		Production Date		2023 - 8 - 2	21	
Maintenance	•		۲P	G		

- Measurement done at output terminals of the EUT, see Figure 3, Figure 4 and Figure 5.
- According to EREC G99, section 15.6.1 the following applies:
- since the rated power of *HPS30* is between $1/\sqrt{10} \cdot P_{n, HPS50}$ and $2 \cdot P_{n, HPS50}$, a family approach to type testing is acceptable.
- A transfer of measurement results from the *HPS50* to other units in the product series according to EREC G99, section 15.6.2 is allowed (for details see section *5* Assessment overview.)
- Technical justification for transferability of measurement results: see section 3.2 on p.11.

4.5 Reference values

Reference values for the p.u. or percentage calculations:

	HPS30	HPS50
Registered Capacity ³ P _{max} [kW]	30.0	50.0
Rated voltage (phase-to-neutral), U_n [V]	23	30
Rated current, In ⁴ [A]	47.0	79.0

4.6 Measurement setup

Tests documented in this test report were performed using the following test configuration:

- □ Measurements in the field on real grid
- □ Test bench tests on real grid
- Test bench tests on an AC grid simulator

The PGU is connected on the DC-side to a PV-simulator and on the AC-side to an AC-grid simulator. The AC-grid simulator is operated with nominal conditions of $U_n = 230$ (phase-to-neutral) and $f_n = 50$ Hz unless stated otherwise by the applied test requirement.

Available primary power is modified by adapting the short circuit current (I_{sc}) value of the I-V curve. Following example shows a PV-curve (I_{sc} = 88.696 A, U_{oc} = 699 V) simulated according to EN50530:



Figure 2 – DC characteristics for testing

The measurement setups are shown in Figure 3 Figure 4 and Figure 5. The specific test and measurement devices are stated in section 4.7.

³ In this report, the stated values of "registered capacity" related to single Generating Unit.

⁴ The rated current stated in this report is calculated based on the "registered capacity" and the rated voltage.



Figure 3 – Measurement setup used for tests except Loss of Mains and Short Circuit test



Figure 4 – Test circuit for Loss of Mains according to IEC 62116:2014





4.7 Measurement equipment

Equipment	Internal No.	Manufacturer	Туре	Serial No.	Next Calibration
DC power	HC-ENG-043	KEWELL	S7000-21K- 2000-0040	6018888221003 326	
supply ⁵	HC-ENG-044	KEWELL	S7000-21K- 2000-0040	6018888221001 316	
	HC-ENG-030	KEWELL	KAC-45-345- 33	6018888220300 485	
AC Simulator ⁵	HC-ENG-038	KEWELL	KAC-45-345- 33	6018888220903 208	
	HC-ENG-039	KEWELL	KAC-45-345- 33	6018888220903 207	
Oscilloscope	HC-ENG-029	DEWETRON	TRION-1820- POWER	A1228623/ C5220751	2024-03-26
Power analyser	HC-ENG-029	DEWETRON	TRION-1820- POWER	A1228623/ C5220751	2024-03-26
	HC-ENG-029-001	LEM	DS CT 400	1221300587	2024-03-26
Current concer	HC-ENG-029-002	LEM	DS CT 400	1221300588	2024-03-26
Current sensor	HC-ENG-029-003	LEM	DS CT 400	1221300595	2024-03-26
	HC-ENG-029-004	LEM	DS CT 400	1221300596	2024-03-26
Digital hygrometer	HC-ENG-002	Jiangsu Jingchuang Electric Co., Ltd.	GSP-8A	CMA215000031	2023-08-31

Note:

All measurement equipment was used within the calibration period. Copy of calibration certificates are available at the laboratory for reference.

⁵ The AC simulator and DC sources do not need to be calibrated, since the AC voltage and current is measured and determined using the calibrated oscilloscope and power analyser.

5 Assessment overview

Possible test case verdicts:

Test item does meet the requirement:	P (Pass)
Test item does not meet the requirement:	F (Fail)
Test case does not apply to the test object:	N/A
Test case is not rated	N/R
Reference to declaration documents	R/D

Items	Technical requirements (Section EREC G99)	Remark / Transfer of measurement results *	Verdict
1. Operating Range	10.3.4, 11.2.1	See section 6.1 / The verified operating range of the HPS50 can be applied to other units in the product series directly.	Р
2. Harmonics	9.4.3	See section 6.2 / The percentage harmonics results of the HPS50 can be considered as worst case results and applied to other units in the product series directly.	Ρ
3. Voltage Fluctuation and Flicker	9.4.2	See section 6.3 / The Flicker results of the HPS50 can be considered as worst case results and applied to other units in the product series directly.	Ρ
4. DC injection	9.4.6	See section 6.4 /	N/A
5. Power Factor (PF)	11.1.5	See section 6.5 / The Power Factor results of the HPS50 can be considered as worst case results and applied to other units in the product series directly.	Ρ
6. Frequency protection trip and ride through tests	10.3, 10.6	See section 6.6.1 / The measurement results of the HPS50 can be considered as worst case results and applied to other units in the product series directly.	Ρ
7. Voltage protection trip and ride through tests	10.3, 10.6	See section 6.6.2 / The measurement results of the HPS50 can be considered as worst case results and applied to other units in the product series directly.	Ρ
8. Protection – Loss of Mains Test, Vector Shift and RoCoF Stability Test	10.3, 10.4, 10.6	See section 6.6.3, 6.6.4 and 6.6.5 / The measurement results of the HPS50 can be considered as worst case results and applied to other units in the product series directly.	Ρ
9. LFSM-O Test	11.2.4	See section 6.7 / The determined droops of the HPS50 can be considered as worst case results and applied to other units in the product series directly.	Ρ

LYNS-TC:

Items	Technical requirements (Section EREC G99)	Remark / Transfer of measurement results *	Verdict
10. Protection – Reconnection Timer	A.7.1.2.5	See section 6.8 / The measurement results of the HPS50 can be considered as worst case results and applied to other units in the product series directly.	Ρ
11. Fault Level Contribution	9.7, A.7.1.5	See section 6.9 / The measurement results of the HPS50 can be considered as worst case results and applied to other units in the product series directly.	Ρ
12. Self-monitoring Solid State Switch	9.7.9	See section 6.10 /	N/A
13. Wiring functional tests if required by para 15.2.1 (attach relevant schedule of tests)	15.2.1	See section 6.11 /	N/A
14. Logic Interface (input port)	11.1.3	See section 6.12 / The measurement results of the HPS50 can be considered as worst case results and applied to other units in the product series directly. The high-level description of logic interface applies to the whole product series.	Ρ
15. Cyber security	9.1.7	See section 6.13 / Manufacturer's declaration provided. See Annex 2 - Manufacturer's declaration regarding Cyber Security.	R/D
Output power with falling frequency	A.7.1.7, 11.2.3.3	Test not required for Power Generating Modules using inverter	N/A

Note:

Conformity statements are decided in accordance with ILAC-G8:09/2019 Binary Statement for Simple Acceptance Rule, unless otherwise normatively specified or contractually agreed.

* According to EREC G99, section 15.6.2 the following applies:

All absolute values (e.g. operating range tests) shall be transferred directly in the compliance forms of an assumed compliant Generating Unit of the same family. All relative results related to design Active Power or current (e.g. power quality fluctuation and flicker) from the tested Generating Unit shall be transferred to the compliance form of a Generating Unit in the same family according to the ratio of the respective nameplate rating (W)of the tested Generating Unit and the assumed compliant Generating Unit. For the avoidance of doubt, the Manufacturer shall register each Generating Unit in the family on the Energy Networks Association Type Test register.

Since the tests were performed on HPS50 which provides the highest current / power, in this report the *relative results* of EUT HPS50 are considered as worst case results and applied to other units in the product series directly.

6 Measurement results

A2-3 Compliance Verification Report –Tests for Type A Inverter Connected Power Generating Modules – test record

6.1 Operating Range

Tests should be carried with the Power Generating Module operating at Registered Capacity and connected to a suitable test supply or grid simulation set. The power supplied by the primary source shall be kept stable within ± 5 % of the apparent power value set for the entire duration of each test sequence.

Frequency, voltage and Active Power measurements at the output terminals of the Power Generating Module shall be recorded every second. The tests will verify that the Power Generating Module can operate within the required ranges for the specified period of time.

The Interface Protection shall be disabled during the tests.

In case of a PV Power Park Module the PV primary source may be replaced by a DC source.

In case of a full converter Power Park Module (eg wind) the primary source and the prime mover Inverter/rectifier may be replaced by a DC source.

Pass or failure of the test should be indicated in the fields below (right hand side), for example with the statement "Pass", "No disconnection occurs", etc. Graphical evidence is preferred.

Note that the value of voltage stated in brackets assumes a LV connection. This should be adjusted for HV as required.







6.2 Power Quality – Harmonics

For Power Generating Modules of Registered Capacity of less than 75 A per phase (ie 50 kW) the test requirements are specified in Annex A.7.1.5. These tests should be carried out as specified in BS EN 61000-3-12, and measurements for the $2^{nd} - 13^{th}$ harmonics should be provided. The results need to comply with the limits of Table 2 of BS EN 61000-3-12 for single phase equipment and Table 3 of BS EN 610000-3-12 for three phase equipment. For three phase Power Generating Modules, measurements for all phases should be provided.

For Power Generating Modules of Registered Capacity of greater than 75 A per phase (ie 50 kW) the installation shall be designed in accordance with EREC G5.

The rating of the **Power Generating Module** (per phase) should be provided below, and the Total Harmonic Distortion (THD) and Partial Weighted Harmonic Distortion (PWHD) should be provided at the bottom of this section.

Power Generating Module tested to BS EN 61000-3-12								
Power Ger (rpp)	Power Generating Module rating per phase rpp)			16.667 kVA		Harmonic % = Measured Value (A) x 23/rating per phase (kVA)		
Single or three phase measurements (for single phase measurements, only complete L1 columns below).				three phase	es			
Harmonic	At 45-55%	of Register	ed Capacity	/			Lim	it in
	Measured	d Value (MV)) in Amps	Measure	ed Value (M	BS EN 61000-3-12		
Order	L ₁	L_2	L ₃	L ₁	L ₂	L ₃	1-phase	3-phases
2	0.8160	0.9455	1.0527	1.1261	1.3049	1.4528	8%	8%
3	0.4362	1.2896	0.8565	0.6019	1.7796	1.1820	21.6%	Not stated
4	0.5651	0.5624	0.6528	0.7798	0.7760	0.9009	4%	4%
5	0.4421	0.3839	0.7407	0.6101	0.5298	1.0222	10.7%	10.7%
6	0.4117	0.0585	0.4701	0.5682	0.0808	0.6488	2.67%	2.67%
7	0.3504	0.1817	0.2245	0.4836	0.2507	0.3098	7.2%	7.2%
8	0.0989	0.1127	0.1119	0.1365	0.1556	0.1545	2%	2%
9	0.0625	0.1031	0.0417	0.0862	0.1423	0.0576	3.8%	Not stated
10	0.0885	0.0892	0.0799	0.1221	0.1231	0.1102	1.6%	1.6%
11	0.1028	0.0748	0.0803	0.1419	0.1032	0.1108	3.1%	3.1%

⁶ The percentage values of harmonic currents (for both partial load and full load tests) were calculated using the formula: Harmonic % = Measured Value (A) x 23/rating per phase (kVA)

according to Form A2-3, which corresponding to a reference current equal to rated current of the inverter.

Order	L ₁	L ₂	L ₃	L ₁	L ₂	L ₃	1-phase	3-phases
12	0.0549	0.0105	0.0640	0.0758	0.0144	0.0883	1.33%	1.33%
13	0.0287	0.0502	0.0319	0.0397	0.0693	0.0440	2%	2%
14	0.0290	0.0259	0.0214	0.0401	0.0358	0.0296		
15	0.0213	0.0174	0.0053	0.0294	0.0240	0.0073		
16	0.0217	0.0155	0.0219	0.0299	0.0214	0.0302		
17	0.0370	0.0330	0.0428	0.0510	0.0456	0.0591		
18	0.0273	0.0025	0.0289	0.0377	0.0034	0.0399		
19	0.0108	0.0154	0.0231	0.0149	0.0213	0.0319		
20	0.0154	0.0147	0.0107	0.0213	0.0202	0.0148		
21	0.0066	0.0028	0.0057	0.0091	0.0039	0.0079		
22	0.0102	0.0084	0.0113	0.0141	0.0116	0.0157		
23	0.0124	0.0135	0.0157	0.0172	0.0186	0.0217		
24	0.0119	0.0040	0.0152	0.0164	0.0055	0.0210		
25	0.0029	0.0085	0.0065	0.0040	0.0118	0.0089		
26	0.0049	0.0086	0.0058	0.0068	0.0119	0.0081		
27	0.0068	0.0037	0.0056	0.0094	0.0051	0.0077		
28	0.0070	0.0044	0.0103	0.0096	0.0061	0.0143		
29	0.0038	0.0099	0.0120	0.0052	0.0136	0.0166		
30	0.0085	0.0058	0.0140	0.0117	0.0080	0.0194		
31	0.0015	0.0031	0.0029	0.0021	0.0043	0.0040		
32	0.0017	0.0058	0.0046	0.0023	0.0080	0.0064		
33	0.0019	0.0013	0.0020	0.0026	0.0018	0.0028		
34	0.0016	0.0055	0.0047	0.0022	0.0075	0.0065		
35	0.0032	0.0014	0.0027	0.0045	0.0019	0.0038		
36	0.0035	0.0026	0.0053	0.0048	0.0035	0.0073		
37	0.0021	0.0015	0.0018	0.0028	0.0020	0.0025		
38	0.0012	0.0015	0.0016	0.0017	0.0021	0.0022		
39	0.0034	0.0015	0.0045	0.0047	0.0021	0.0061		
40	0.0026	0.0031	0.0055	0.0036	0.0043	0.0075		
THD 7				1.8015	2.4298	2.4399	23%	13%
PWHD ⁸				0.4098	0.3476	0.4559	23%	22%

⁷ THD = Total Harmonic Distortion, order 2 - 40 according to BS EN 61000- 3-12 considered. The stated values in the results table are in %. ⁸ PWHD = Partial Weighted Harmonic Distortion, order 14 - 40 according to BS EN 61000- 3-12 considered. The stated values in the results table are in %.

Harmonic	At 100% of Registered Capacity					Limit in BS	EN 61000-3-	
	Measure	d Value (MV) in Amps	Measure	ed Value (M	V) in % ⁶	1	2
Order	L ₁	L ₂	L ₃	L ₁	L ₂	L ₃	1-phase	3-phases
2	0.8111	1.0810	1.3300	1.1193	1.4918	1.8354	8%	8%
3	0.3731	1.6405	1.2668	0.5148	2.2638	1.7482	21.6%	Not stated
4	0.7203	0.7278	0.9590	0.9940	1.0043	1.3234	4%	4%
5	0.5419	0.2494	0.7454	0.7478	0.3441	1.0287	10.7%	10.7%
6	0.5224	0.1311	0.6529	0.7209	0.1809	0.9010	2.67%	2.67%
7	0.2277	0.0420	0.1878	0.3143	0.0580	0.2592	7.2%	7.2%
8	0.1442	0.1537	0.1524	0.1990	0.2121	0.2103	2%	2%
9	0.0421	0.0712	0.0305	0.0580	0.0983	0.0421	3.8%	Not stated
10	0.0875	0.0644	0.0478	0.1207	0.0889	0.0660	1.6%	1.6%
11	0.1423	0.1656	0.1460	0.1964	0.2285	0.2014	3.1%	3.1%
12	0.0293	0.0055	0.0338	0.0404	0.0076	0.0467	1.33%	1.33%
13	0.0833	0.0575	0.0740	0.1150	0.0793	0.1021	2%	2%
14	0.0184	0.0202	0.0045	0.0254	0.0279	0.0063		
15	0.0099	0.0086	0.0136	0.0136	0.0119	0.0188		
16	0.0175	0.0163	0.0245	0.0241	0.0225	0.0338		
17	0.0484	0.0671	0.0517	0.0667	0.0926	0.0713		
18	0.0233	0.0067	0.0296	0.0321	0.0092	0.0409		
19	0.0564	0.0374	0.0411	0.0778	0.0516	0.0567		
20	0.0043	0.0121	0.0108	0.0060	0.0168	0.0149		
21	0.0141	0.0123	0.0071	0.0194	0.0170	0.0098		
22	0.0087	0.0126	0.0144	0.0121	0.0174	0.0199		
23	0.0247	0.0154	0.0109	0.0341	0.0213	0.0150		
24	0.0157	0.0084	0.0226	0.0217	0.0115	0.0312		
25	0.0177	0.0266	0.0155	0.0244	0.0367	0.0213		
26	0.0117	0.0078	0.0131	0.0162	0.0107	0.0181		
27	0.0112	0.0038	0.0081	0.0155	0.0052	0.0112		
28	0.0106	0.0028	0.0083	0.0146	0.0039	0.0114		
29	0.0139	0.0132	0.0195	0.0191	0.0182	0.0269		
30	0.0090	0.0037	0.0105	0.0125	0.0051	0.0146		
31	0.0066	0.0087	0.0092	0.0091	0.0120	0.0126		
32	0.0041	0.0068	0.0048	0.0057	0.0094	0.0067		
33	0.0029	0.0022	0.0028	0.0041	0.0030	0.0038		
34	0.0057	0.0051	0.0066	0.0079	0.0071	0.0091		
35	0.0068	0.0076	0.0078	0.0093	0.0105	0.0107		
36	0.0076	0.0041	0.0112	0.0105	0.0056	0.0155		
37	0.0039	0.0064	0.0050	0.0053	0.0089	0.0070		
38	0.0036	0.0052	0.0058	0.0050	0.0071	0.0080		
39	0.0031	0.0024	0.0038	0.0043	0.0034	0.0052		
40	0.0054	0.0043	0.0091	0.0074	0.0060	0.0126		
THD 7				1.9525	2.9413	3.1990	23%	13%
PWHD ⁸				0.5898	0.5657	0.5777	23%	22%

6.3 Power Quality – Voltage fluctuations and Flicker

For **Power Generating Modules** of **Registered Capacity** of less than 75 A per phase (ie 50 kW) these tests should be undertaken in accordance with Annex A.7.1.4.3. Results should be normalised to a standard source impedance, or if this results in figures above the limits set in BS EN 61000-3-11 to a suitable Maximum Impedance.

For **Power Generating Modules** of **Registered Capacity** of greater than 75 A per phase (ie 50 kW) the installation shall be designed in accordance with EREC P28.

The standard test impedance is 0.4 Ω for a single-phase **Power Generating Module** (and for a two-phase unit in a three-phase system) and 0.24 Ω for a three phase **Power Generating Module** (and for a two-phase unit in a split phase system). Please ensure that both test and standard impedance are completed on this form. If the test impedance (or the measured impedance) is different to the standard impedance, it must be normalised to the standard impedance as follows (where the **Power Factor** of the generation output is 0.98 or above):

d_{max} normalised value = (Standard impedance / Measured impedance) x Measured value.

Where the **Power Factor** of the output is under 0.98 then the X to R ratio of the test impedance should be close to that of the standard impedance.

The stopping test should be a trip from full load operation.

The duration of these tests needs to comply with the particular requirements set out in the testing notes for the technology under test.

Test start date 2023-08-18 Test end date 2023-08-18 Test location Lyns-tci Technology Guangdong Co., Ltd. (see Testing location on p.2) Starting Stopping Running P_{st} Phase no. dmax [%] dc[%] d(t) [ms] dmax [%] dc[%] d(t) [ms] Plt2 hours L1 0.309 0.058 0.000 1.906 0.339 0.000 0.014 0.013 Measured 12 0.247 0.000 0.507 0.000 0.014 0.031 0.199 0.014 Values at L3 0.259 0.012 0.000 1.884 0.435 0.000 0.019 0.014 test impedance Overall 0.259 0.058 0.000 1.906 0.435 0.000 0.019 0.014 worst case L1 0.309 0.058 0.000 1.906 0.339 0.000 0.014 0.013 L2 0.000 0.014 0.247 0.031 0.507 0.199 0.000 0.014 Normalised to standard 13 0.259 0.019 0.012 0.000 1.884 0.435 0.000 0.014 impedance Overall 0.014 0.259 0.058 0.000 1.906 0.435 0.000 0.019 worst case L1 ----------------------Normalised L2 ----------------------to required L3 --------maximum -------------impedance Overall ----------worst case Limits set under BS 500 500 4 3.3 4 3.3 1.0 0.65 EN 61000-(3.3%) (3.3%)3-11 Test R: 0.24 Ω Х: 0.15 Ω Impedance Standard \boxtimes 0.24 * \boxtimes 0.15 * Х: R: Ω Ω Impedance 0.4 ^ 0.25 ^ Maximum R: Ω Х: Ω 1.548 0.968 Impedance * three-phase Power Generating Modules split single phase Power Generating \square **Modules** ۸ single phase Power Generating Module Power Generating Modules using two phases on a three-phase system

The test date and location must be declared.

6.4 Power Quality – DC injection

The tests should be carried out on a single **Generating Unit**. Tests are to be carried out at three defined power levels $\pm 5\%$. At 230 V a 50 kW three phase **Inverter** has a current output of 217 A so DC limit is 543 mA. These tests should be undertaken in accordance with Annex A.7.1.4.4.

The % DC injection ("as % of rated AC current" below) is calculated as follows:

% DC injection = Recorded DC value in Amps / Base current

where the base current is the **Registered Capacity** (W) / V_{phase} *. The % DC injection should not be greater than 0.25%.

Test power level	10%	55%	100%
Recorded DC value in Amps			
as % of rated AC current			
Limit [%]			

Note:

* Calculation is the same for 1 phase and 3 phase devices:

- Base current = Registered Capacity (W) / 230 (V)

- % DC injection = Recorded DC value (A) / Base current (A) *100

Note:

The unit is equipped with a build-in transformer on the AC side of the inverter. Tests are omitted (see also EREC G99, section 9.4.6.2).

6.5 Power Factor

The tests should be carried out on a single **Power Generating Module**. Tests are to be carried out at three voltage levels and at **Registered Capacity** and the measured **Power Factor** must be greater than 0.95 to pass. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test. These tests should be undertaken in accordance with Annex A.7.1.4.2.

Note that the value of voltage stated in brackets assumes a ${\bf LV}$ connection. This should be adjusted for ${\bf HV}$ as required.

Voltage	0.94 pu (216.2 V)	1 pu (230 V)	1.1 pu (253 V)
Measured value	0.997	0.996	0.992
Power Factor Limit	>0.95	>0.95	>0.95

Note:

The Power Park Modules (Generating Units) considered in this report are designed to be capable of operating within the range ± 0.95 Power Factor at Registered Capacity.

- Max. operating range of Power Factor at Registered Capacity: 0.909 lagging to 0.909 leading
- Setting range of the Power Factor: 0.800 lagging to 0.800 leading

6.6 Protection

The Interface Protection setting information can be displayed in one or more of the following ways:

- \boxtimes A display on a screen which can be read
- A display on an electronic device which can communicate with the Power Generating Module and confirm that it is the correct device by means of a Identification number / name permanently fixed to the device and visible on the electronic device screen at the same time as the settings
- Display of all settings including nominal voltage and current outputs, alongside the identification number / name of the device, permanently fixed to the Power Generating Module
- □ Other (please specify)

Note:

The protection device considered in this report is the integrated protection relay / generating unit switch in the Power Generating Modules.

Manufacturer Data:

The integrated Interface Protection in the Power Generating Modules considered in this report is capable of measuring voltage to an accuracy of $\pm 1.5\%$ of the nominal value and of measuring frequency to $\pm 0.2\%$ of the nominal value across its operating range of voltage, frequency and temperature (-30°C ~ +60°C).

(See also subsections 6.6.1 ~ 6.6.5 below)

6.6.1 Protection – Frequency tests

These tests should be carried out in accordance with the Annex A.7.1.2.3. For trip tests, frequency and time delay should be stated. For "no trip tests", "no trip" can be stated.

Function	Setting		Trip test		"No trip	o tests"
	Frequency	Time delay	Frequency	Time delay	Frequency / time	Confirm no trip
U/F stage 1	47.5 Hz	20 s	47.51 Hz	20.051s	47.7 Hz 30 s	No trip occurred
U/F stage 2	47 Hz	0.5 s	47.03 Hz	0.595 s	47.2 Hz 19.5 s	No trip occurred
					46.8 Hz 0.45 s	No trip occurred
O/F	52 Hz	0.5 s	52.02 Hz	0.517 s	51.8 Hz 120.0 s	No trip occurred
					52.2 Hz 0.45 s	No trip occurred

Note:

for frequency trip tests the frequency required to trip is the setting \pm 0.1 Hz. In order to measure the time delay a larger deviation than the minimum required to operate the projection can be used. The "No trip tests" need to be carried out at the setting \pm 0.2 Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.



Figure 6 – Test U/F stage 1 (Trip test)



Figure 7 – Test U/F stage 2 (Trip test)



Figure 8 – Test OF (Trip test)

6.6.2 Protection – Voltage tests

These tests should be carried out in accordance with Annex A.7.1.2.2. For trip tests, voltage and time delay should be stated. For "no trip tests", "no trip" can be stated.

Note that the value of voltage stated below assumes a LV connection This should be adjusted for HV taking account of the VT ratio as required.

Function		Set	Setting Trip test		Setting Trip test "No trip		o tests"
		Voltage	Time delay	Voltage	Time delay	Voltage / time	Confirm no trip
	L1-N			183.9 V	2.516 s		No trip occurred
U/V	L2-N	0.8 pu (184 V)	2.5 s	183.7 V	2.517 s	188 V 5.0 s	No trip occurred
	L3-N			184.5 V	2.514 s		No trip occurred
						180 V 2.45 s	No trip occurred
	L1-N			263.1 V	1.009 s		No trip occurred
O/V stage 1	L2-N	1.14 pu (262.2 V)	1.0 s	262.8 V	1.044 s	258.2 V 5.0 s	No trip occurred
	L3-N			263.8 V	1.004 s		No trip occurred
	L1-N			273.2 V	0.545 s		No trip occurred
O/V stage 2	L2-N	1.19 pu (273.7 V)	0.5 s	273.2 V	0.542 s	269.7 ∨ 0.95 s	No trip occurred
	L3-N			274.2 V	0.531 s		No trip occurred
						277.7 V 0.45 s	No trip occurred

Note:

for voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.





Figure 9 – Test U/V (Trip test, L1-N)



Figure 10 – Test U/V (Trip test, L2-N)





Figure 11 – Test U/V (Trip test, L3-N)



Figure 12 – Test O/V stage 1 (Trip test, L1-N)





Figure 13 – Test O/V stage 1 (Trip test, L2-N)



Figure 14 – Test O/V stage 1 (Trip test, L3-N)



Figure 15 – Test O/V stage 2 (Trip test, L1-N)



Figure 16 – Test O/V stage 2 (Trip test, L2-N)



Figure 17 – Test O/V stage 2 (Trip test, L3-N)

6.6.3 Protection – Loss of Mains test

These tests should be carried out in accordance with BS EN 62116. Annex A.7.1.2.4.						
The following sub	set of tests sho	uld be recorded	in the following	table.		
Test Power and imbalance 33% 66% 100% 33% 66% 100% (Test 22) -5%Q -5%P +5%Q +5%Q +5%P (Test 22) (Test 12) (Test 5) (Test 31) (Test 21) (Test 10)						
Trip time [s]	0.044	0.027	0.247	0.038	0.033	0.208
Trip time limit [s] 0.5 ⁹						
Note: For full testing according to BS EN 62116 see Annex 1 - Loss of Mains test according to BS EN 62116						

6.6.4 Loss of Mains Protection, Vector Shift Stability test

This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the **Power Generating Module** does not trip under positive / negative vector shift.

The following sub set of tests should be recorded in the following table.

-			-
	Start Frequency	Change	Confirm no trip
Positive Vector Shift	49.5 Hz	+50 degrees	No trip occurred
Negative Vector Shift	50.5 Hz	- 50 degrees	No trip occurred

⁹ If the device requires additional shut down time (beyond 0.5 s but less than 1 s) then this should be stated on this form.



Figure 19 – Negative Step Change (-50 degrees)

6.6.5 Loss of Mains Protection, RoCoF Stability test

This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the Power Generating Module does not trip for the duration of the ramp up and ramp down test.					
The following sub set of tests should be recorded in the following table.					
Ramp range	Test frequency ramp:	Test Duration	Confirm no trip		
49.0 Hz to 51.0 Hz +0.95 Hz/s 2.1 s No trip occurred					
51.0 Hz to 49.0 Hz -0.95 Hz/s 2.1 s No trip occurred					
Note:	Note:				

During the test, the LFSM-O function was activated.







Figure 21 – Negative Frequency Drift (-0.95 Hz/s)

6.7 Limited Frequency Sensitive Mode – Overfrequency test

The test should be carried out using the specific threshold frequency of 50.4 Hz and **Droop** of 10%. This test should be carried out in accordance with Annex A.7.1.3, which also contains the measurement tolerances.

Active Power response to rising frequency/time plots are attached if frequency injection tests are undertaken in accordance with Annex A.7.2.4.

Alternatively, test results should be noted below:

Alternatively, lest results should be holed below.				
Test sequence at Registered Capacity >80%	Measured Active Power Output [W]	Frequency [Hz]	Primary Power Source [W]	Active Power Gradient Droop
Step a) 50.00Hz ± 0.01Hz	50105	50.00		
Step b) 50.45Hz ± 0.05Hz	49575	50.45		9.43% ¹⁾
Step c) 50.70Hz ± 0.10Hz	46980	50.70		9.63% ²⁾
Step d) 51.15Hz ± 0.05Hz	42493	51.15	25500	10.03% ³⁾
Step e) 50.70Hz ± 0.10Hz	46958	50.70		10.08% ⁴⁾
Step f) 50.45Hz ± 0.05Hz	49519	50.45		9.76% ⁵⁾
Step g) 50.00Hz ± 0.01Hz	49988	50.00		
	(calculated using fre	9.88%		
	(calculated using free	9.96%		
			1 / //	
Test sequence at Registered Capacity 40% - 60%	Measured Active Power Output [W]	Frequency [Hz]	Primary Power Source [W]	Active Power Gradient Droop
Test sequence at Registered Capacity 40% - 60% Step a) 50.00Hz ± 0.01Hz	Measured Active Power Output [W] 25020	Frequency [Hz] 50.00	Primary Power Source [W]	Active Power Gradient Droop
Test sequence at Registered Capacity 40% - 60% Step a) 50.00Hz ± 0.01Hz Step b) 50.45Hz ± 0.05Hz	Measured Active Power Output [W] 25020 24518	Frequency [Hz] 50.00 50.45	Primary Power Source [W]	Active Power Gradient Droop 9.96% ¹⁾
Test sequence at Registered Capacity $40\% - 60\%$ Step a) $50.00Hz \pm 0.01Hz$ Step b) $50.45Hz \pm 0.05Hz$ Step c) $50.70Hz \pm 0.10Hz$	Measured Active Power Output [W] 25020 24518 21985	Frequency [Hz] 50.00 50.45 50.70	Primary Power Source [W]	Active Power Gradient Droop 9.96% ¹⁾ 9.87% ²⁾
Test sequence at Registered Capacity $40\% - 60\%$ Step a) $50.00Hz \pm 0.01Hz$ Step b) $50.45Hz \pm 0.05Hz$ Step c) $50.70Hz \pm 0.10Hz$ Step d) $51.15Hz \pm 0.05Hz$	Measured Active Power Output [W] 25020 24518 21985 17503	Frequency [Hz] 50.00 50.45 50.70 51.15	Primary Power Source [W]	Active Power Gradient Droop 9.96% ¹⁾ 9.87% ²⁾ 10.04% ³⁾
Test sequence at Registered Capacity $40\% - 60\%$ Step a) $50.00Hz \pm 0.01Hz$ Step b) $50.45Hz \pm 0.05Hz$ Step c) $50.70Hz \pm 0.10Hz$ Step d) $51.15Hz \pm 0.05Hz$ Step e) $50.70Hz \pm 0.10Hz$	Measured Active Power Output [W] 25020 24518 21985 17503 21991	Frequency [Hz] 50.00 50.45 50.70 51.15 50.70 50.70	Primary Power Source [W] 13000	Active Power Gradient Droop 9.96% ¹⁾ 9.87% ²⁾ 10.04% ³⁾ 10.03% ⁴⁾
Test sequence at Registered Capacity 40% - 60% Step a) $50.00Hz \pm 0.01Hz$ Step b) $50.45Hz \pm 0.05Hz$ Step c) $50.70Hz \pm 0.10Hz$ Step d) $51.15Hz \pm 0.05Hz$ Step e) $50.70Hz \pm 0.10Hz$ Step f) $50.45Hz \pm 0.05Hz$	Measured Active Power Output [W] 25020 24518 21985 17503 21991 24525	Frequency [Hz] 50.00 50.45 50.70 51.15 50.70 50.45	Primary Power Source [W]	Active Power Gradient Droop 9.96% ¹⁾ 9.87% ²⁾ 10.04% ³⁾ 10.03% ⁴⁾ 9.87% ⁵⁾
Test sequence at Registered Capacity $40\% - 60\%$ Step a) $50.00Hz \pm 0.01Hz$ Step b) $50.45Hz \pm 0.05Hz$ Step c) $50.70Hz \pm 0.10Hz$ Step d) $51.15Hz \pm 0.05Hz$ Step e) $50.70Hz \pm 0.10Hz$ Step f) $50.45Hz \pm 0.05Hz$ Step g) $50.45Hz \pm 0.05Hz$	Measured Active Power Output [W] 25020 24518 21985 17503 21991 24525 25017	Frequency [Hz] 50.00 50.45 50.70 51.15 50.70 50.45 50.70 51.15 50.70 50.45	Primary Power Source [W]	Active Power Gradient Droop 9.96% ¹⁾ 9.87% ²⁾ 10.04% ³⁾ 10.03% ⁴⁾ 9.87% ⁵⁾
Test sequence at Registered Capacity $40\% - 60\%$ Step a) $50.00Hz \pm 0.01Hz$ Step b) $50.45Hz \pm 0.05Hz$ Step c) $50.70Hz \pm 0.10Hz$ Step d) $51.15Hz \pm 0.05Hz$ Step e) $50.70Hz \pm 0.10Hz$ Step f) $50.45Hz \pm 0.05Hz$ Step f) $50.45Hz \pm 0.05Hz$ Step g) $50.00Hz \pm 0.01Hz$	Measured Active Power Output [W] 25020 24518 21985 17503 21991 24525 25017 (calculated using free	Frequency [Hz] 50.00 50.45 50.70 51.15 50.70 50.45 50.70 51.15 50.70 50.45 50.00 50.45 50.70 51.15 50.70 50.45 50.00 1st Droop equency and power be 1000	Primary Power Source [W] 13000	Active Power Gradient Droop 9.96% ¹⁾ 9.87% ²⁾ 10.04% ³⁾ 10.03% ⁴⁾ 9.87% ⁵⁾ 9.98%

Note:

- * Test according to Annex A.7.1.3. Frequency/time plots attached (see Figure 22 & Figure 23)
- ¹⁾ Droop calculated using frequency and power between steps b) & threshold frequency of 50.4 Hz
- ²⁾ Droop calculated using frequency and power between steps c) & b)
- ³⁾ Droop calculated using frequency and power between steps d) & c)
- ⁴⁾ Droop calculated using frequency and power between steps e) & d)
- ⁵⁾ Droop calculated using frequency and power between steps f) & e)



P_[W] Frequency_[Hz]

Figure 22 – Test sequence at Registered Capacity >80%



Figure 23 – Test sequence at Registered Capacity 40% - 60%

6.8 **Protection – Re-connection timer**

Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 10.1. Both the time delay setting and the measured delay should be provided in this form; both should be greater than 20 s to pass. Confirmation should be provided that the **Power Generating Module** does not reconnect at the voltage and frequency settings below; a statement of "no reconnection" can be made.

Time delay setting	Measured delay	Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of Table 10.1.			
60 s	64 s	At 1.16 pu (266.2 V LV At 0.78 pu (180.0 V LV At 47.4 Hz At 52.1 Hz connection) connection) connection connection connection			
Confirmation that the Power Generating Module does not re- connect.		No reconnection occurred	No reconnection occurred	No reconnection occurred	No reconnection occurred

6.9 Fault level contribution

These tests shall be carried out in accordance with EREC G99 Annex A.7.1.5. Please complete each entry, even if the contribution to the fault level is zero.

For Inverter output				
Time after fault	Volts	Amps		
	L1: 153.5	L1: 30.6		
20ms	L2: 144.8	L2: 33.1		
	L3: 243.3	L3: 5.2		
	L1: 36.2	L1: 0.07		
100ms	L2: 17.6	L2: 0.08		
	L3: 16.6	L3: 0.06		
	L1: 35.6	L1: 0.07		
250ms	L2: 17.6	L2: 0.08		
	L3: 17.1	L3: 0.07		
	L1: 35.6	L1: 0.07		
500ms	L2: 17.4	L2: 0.09		
	L3: 17.6	L3: 0.07		
Time to trip	0.004	In seconds		

6.10 Self-Monitoring solid state switching

No specified test requirements. Refer to Annex A.7.1.6.	
It has been verified that in the event of the solid-state switching device failing to disconnect the Power Park Module , the voltage on the output side of the switching device is reduced to a value below 50 volts within 0.5 s.	N/A
Note:	

The PGU used electromechanical relay to disconnect from the grid. No solid-state switching device available.

6.11 Wiring functional tests

If required by para 15.2.1.	
Confirm that the relevant test schedule is attached (tests to be undertaken at time of commissioning)	N/A
Note:	
Tests carried out in laboratory, specifically designed plugs and sockets used.	

6.12 Logic interface (input port)

Confirm that an input port is provided and can be used to shut down the module	Yes
Provide high level description of logic interface, e.g. details in 11.1.3.1 such as AC or DC signal (the additional comments box below can be used)	Yes
Note:	
For details see "Additional comments." Below.	

~ [V] 11 • 12 [A] • 13 [A] Signal [V] 0:14.7 Time [s] A 0:15.371787 B 0:15.518984 Delta 0.147197 I1 [A]
I2 [A]
I3 [A]
Signal [V] -1.557469 0.454187 0.928044 -3.730536 51.56279 43.04052 -94.95199 -6.648541 -53.12026 -42.58633 95.88004 2.918005

Figure 24 – Test ceasing active power output using logic interface

6.13 Cyber security

provided. See Annex 2 - Manufacturer's declaration regarding Cyber Security.	Confirm that the Power Generating Module has been designed to comply with cyber security requirements, as detailed in 9.1.7.	Yes. Manufacturer's declaration provided. See Annex 2 - Manufacturer's declaration regarding Cyber Security.
--	---	--

Additional comments.

High level description of logic interface:

The PGU equipped with a logic interface for ceasing active power output within 5 s following an instruction being received. The following is a possible configuration (if another configuration is required, this can be agreed with the manufacturer):

EMS mode RS485 command (EMS mode is DRM mode)

Power on command		01 06 00 00 00	0 01 48 0A		
Power off command		01 06 00 00 00	0 00 89 CA		
Turn on EMS mode	01 06 00 20 00 01 49 C0				
Turn off EMS mode		01 06 00 20 0	0 00 88 00		
Rectify AC→DC		01 06 00 22 0	0 01 E8 00		
Inverter DC→AC		01 06 00 22 00	0 00 29 C0		
0% rater DC/AC power		01 06 00 23 0	0 00 78 00		
25% rater DC/AC power	01 06 00 23 00 0D B9 C5	01 06 00 23 00 19 B9 CA	01 06 00 23 00 1E F8 08	01 06 00 23 00 26 F9 DA	
50% rater DC/AC power	01 06 00 23 00 19 B9 CA	01 06 00 23 00 32 F9 D5	01 06 00 23 00 3C 78 11	01 06 00 23 00 4B 38 37	
75% rater DC/AC power	01 06 00 23 00 26 F9 DA	01 06 00 23 00 4B 38 37	01 06 00 23 00 5A F8 3B	01 06 00 23 00 71 B8 24	
50% rated PV power	01 06 00 21 00 19 18 0A	01 06 00 21 00 32 58 15	01 06 00 21 00 3C D9 D1	01 06 00 21 00 4B 99 F7	
100% rated PV power	01 06 00 21 00 32 58 15	01 06 00 21 00 64 D8 2B	01 06 00 21 00 78 D9 E2	01 06 00 21 00 96 59 AE	

Rs485 instruction formula description

AB CD EF GH IJ KL MN OP AB:485 communication address

CD:Function code

EF GH:Register address

IJ KM:Value

MN OP:CRC check value of the first 6 bits

The appendix only shows part of the power section instructions. Please write the required instructions according to the 485 instruction formula and control the ATESS Modbus RTU protocol.

Logic for remote shutdown:

The server sends instructions to the monitoring box, which is sent to the control board through a 485 command. The control board sends a hardware signal to shut down the device.

Annex 1 - Lo	oss of Mains tes	t according to	OBSEN 62116
--------------	------------------	----------------	-------------

No.	P _{EUT} ^a	Reactive load	P _{AC} ^b	Q _{AC} ^c	Run on time	P _{EUT}	Actual	V _{DC}	Remarks ^d
	(% of EUT rating)	(% of Q _L in 6.1d)1))	(% of nominal)	(% of nominal)	(ms)	(VV)	Q _f	(Vdc)	
1	100	100	0	0	267	49985	1.000	720	Test A at BL
2	66	66	0	0	41	33021	1.000	720	Test B at BL
3	33	33	0	0	19	16750	1.000	720	Test C at BL
4	100	100	-5	-5	223	47512	1.026	720	Test A at IB
5	100	100	-5	0	247	47517	1.053	720	Test A at IB
6	100	100	-5	+5	247	47514	1.079	720	Test A at IB
7	100	100	0	-5	254	49992	0.975	720	Test A at IB
8	100	100	0	+5	254	49988	1.025	720	Test A at IB
9	100	100	+5	-5	212	52512	0.928	720	Test A at IB
10	100	100	+5	0	208	52525	0.952	720	Test A at IB
11	100	100	+5	+5	213	52518	0.976	720	Test A at IB
12	66	66	0	-5	27	33011	0,974	640	Test B at IB
13	66	66	0	-4	41	33016	0,980	640	Test B at IB
14	66	66	0	-3	46	33019	0,985	640	Test B at IB
15	66	66	0	-2	39	33016	0,990	640	Test B at IB
16	66	66	0	-1	34	33024	0,995	640	Test B at IB
17	66	66	0	1	48	33026	1,005	640	Test B at IB
18	66	66	0	2	33	33017	1,010	640	Test B at IB
19	66	66	0	3	97	33013	1,015	640	Test B at IB
20	66	66	0	4	41	33018	1,020	640	Test B at IB
21	66	66	0	5	33	33025	1,024	640	Test B at IB
22	33	33	0	-5	44	16753	0,975	544	Test B at IB
23	33	33	0	-4	52	16759	0,980	544	Test B at IB
24	33	33	0	-3	30	16756	0,985	544	Test B at IB
25	33	33	0	-2	33	16752	0,990	544	Test B at IB
26	33	33	0	-1	32	16750	0,995	544	Test B at IB
27	33	33	0	1	55	16750	1,005	544	Test B at IB
28	33	33	0	2	46	16746	1,010	544	Test B at IB
29	33	33	0	3	29	16752	1,015	544	Test B at IB
30	33	33	0	4	45	16759	1,020	544	Test B at IB
31	33	33	0	5	38	16754	1,025	544	Test B at IB

^a P_{EUT} : EUT output power.

^b P_{AC}: Active power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.

^c Q_{AC}: Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value.

^d BL: balance condition, IB: imbalance condition.

Annex 2 - Manufacturer's declaration regarding Cyber Security



Manufacture's Declaration

Confirmation of compliance with the requirement of cybersecurity in standard G99-1

We hereby confirm that all Atess inverters listed below comply with Engineering Recommendation G99, Issue 1-Amendment 9.3 October 2022(section 9.1.7 and 9.1.8) about "cybersecurity" requirement

-Hybrid Inverter HPS30, HPS50, HPS100, HPS120, HPS150

The cybersecurity statement is described as follow:

The communication between Atess Inverter and external communication device is shown as following scheme:



- All communication between the inverter and the external communication device is over the appropriate serial line (RS485), and the inverter only support ATESS's own Modbus protocol
- 2. The communication between the inverter and the network infrastructure normally is constituted by the communication module (WiFi-stick) on the inverter via the WLAN. The communication module (WiFi-stick) have been tested by SGS and got the certificate according to the standard ETSI EN303 645. The communication is made secure by use of Transport Layer Security technology on Communication module, and by the use of Secure Socket Layer technology on User's device side and installer/service web-tools side.
- 3. If the communication between the inverter and the network infrastructure normally is constituted by the third-party device, Atess needs the communication protocol provided

Shenzhen Atess Power Technology Co.,Ltd

2nd Floor, No.23 Zhulongtian Road, Shuitian Community, Shiyan Street, Baoan District, Shenzhen Tel: +86 0755-29988492





by the third-party, and has reached an agreement with the Atess inverter. The data transmission can be protected by Transport Layer Security technology or Secure Socket Layer technology. The network security between third-party devices and third-party servers/clouds will be the responsibility of the third party itself.

4. The cyber-security assessment of the Atess inverter together with the Communication module(WiFi stick) was performed according to the ETSI EN303 645 standard, and the test report of Communication module(WiFi stick) can be the reference document.

Shenzhen, China 2023-06-14 Shenzhen Atess Power Technology Co.,Ltd

Shenzhen Atess Power Technology Co.,Ltd 2nd Floor, No.23 Zhulongtian Road, Shuitian Community, Shiyan Street, Baoan District, Shenzhen Tel: +86 0755-29988492



Annex 3 - CE declaration

Shenzhen Atess Power Technology Co., Ltd

1st Floor of Building 3 at Sector B and 3rd Floor or Building 9, Henglong Industrial Park, Shuitian, Baoan District, Shenzhen, Guangdong Province, P.R. China

Tel: 13760487863

Email: duoxiang.yu@atesspower.com

EU Declaration of Conformity

Product: Hybrid Inverter Model:HPS 30, HPS 50 HPS 100,HPS 120,HPS 150 Name and address of the manufacturer: Shenzhen Atess Power Technology Co., Ltd This declaration of conformity is issued under the sole responsibility of the manufacturer. Also this product is under manufacturer's warranty. Object of the declaration: Hybrid InverterHPS 30, HPS 50, HPS 100,HPS 120,HPS 150



The object of the declaration described above is in conformity with the relevant Union harmonisation legislation: The Low Voltage Directive (LVD) 2014/35/EU and the Electromagnetic Compatibility (EMC) Directive 2014/30/EU.

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

LVD:	
EN 62109-1:2010	•
EN 62109-2:2011	•
EMC:	
EN 61000-6-11:2011+ AC:2000	•
EN 61000-6-2:2005	•

Additional information: CE mark was affixed on the product since 2018.

me

Yu Duoxiang Senior Standard andCettificationEngineer On behalf ofShenzhen Atess Power Technology Co., Ltd 2021-11-02 Place:Shenzhen,China

LYNS-TC:

Annex 4 - ISO 9001 certificate



Annex 5 - Photo of the unit

Enclosure front view



Enclosure side view



Enclosure rear view





Internal view-1



Internal view-2



>>>>> End of Test Report <<<<<