



Ningbo Ginlong Technologies Co., Ltd.

Solis EPM Test Report

Manufacturer: Ningbo Ginlong Technologies Co., Ltd.

No.57 jintong Road, Seafront (Bin Hai) Industrial park, Xiangshan
Demonstration Industrial
Estate, Xiangshan, Ningbo, Zhejiang, 315712, P.R. China

Product: In-built Export Power Manager

Models: Solis-MINI-4G (700W – 3600W) Range
Solis-1P4G (2.5kW – 6kW) Range

Test: Export power manager load change reaction time

Tested: Zhang Yujuan Test date 2017.9.4

Approved: Shi Chenguang Test date 2017.9.4

Date: 2017-09-07

Valid until: 2022-09-07

Manufacture Stamp

Date and place

Ningbo
2017-09-07

宁波锦浪新能源科技有限公司
NINGBO GINLONG TECHNOLOGIES CO., LTD.



Zhangkun
Zhangkun



Ningbo Ginlong Technologies Co.,Ltd.

Equipment List

	Device Name	Model	Quantity
1	DC source	62150H-600S	1
2	Grid Voltage	220V	1
3	Current Amplifier	TCPA300	1
4	Current Probe	TCP303	1
5	Resistance box	62150H-600S	1

Test Conditions		Model: Solis-1P5K-4G; DC Input: 370V 15A	
Backflow Power	Load Power(W)	Inverter Output Current Response Time (Sec)	Waveform
0	6000 → 0W	1.52S	
0	0 → 6000W	1.53S	

Comments

The test result is based on Solis-1P5K-4G. All the series of inverters electrical character are the same. So the test result can cover all series.