

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.* R 50474441
Blatt *Sheet* 0002

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum	<i>Date of Issue</i>
Ruyi Pan	01-QJL-60392592 001	15.07.2020	(day/mo/yr)

Genehmigungsinhaber <i>License Holder</i>	Fertigungsstätte <i>Manufacturing Plant</i>
Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China	Ginlong technologies Co., Ltd. No.57 Jintong Road, Binhai, (seafront), Industrial Park, Xiangshan Ningbo 315712 Zhejiang P.R. China

Prüfzeichen *Test Mark*



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1111226663

Geprüft nach *Tested acc. to*

IEC 62109-1:2010
IEC 62109-2:2011
EN 62109-1:2010
EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

PV-Wechselrichter (Grid-connected PV Inverter)

as page 0001 continuation

Protective Class : Class I
Ingress Protection (IP) : IP66
Pollution Degree (PD) : PD3
Operating Temperature [°C]: -25 to 60 (> 45 derating)
Altitude [m] : ≤4000
Type of Inverter : Non-Isolated

The installation has to be carried out according to the attached installation instruction.
Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Bruce Li

Bruce Li

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.* R 50474441
Blatt *Sheet* 0001

Ihr Zeichen *Client Reference* Ruyi Pan
Unser Zeichen *Our Reference* 01-QJL-60392592 001
Ausstellungsdatum *Date of Issue* 15.07.2020
(day/mo/yr)

Genehmigungsinhaber *License Holder*
Ginlong technologies Co., Ltd.
No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*
Ginlong technologies Co., Ltd.
No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1111226663

Geprüft nach *Tested acc. to*

IEC 62109-1:2010
IEC 62109-2:2011
EN 62109-1:2010
EN 62109-2:2011

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

PV-Wechselrichter (Grid-connected PV Inverter)

Type Designation	: Solis-208K-EHV-5G	9
	Solis-255K-EHV-5G	
Vmax PV [Vd.c.]	: 1500	
Isc PV [Ad.c.]	: 40*9	40*14
MPP Voltage Range [Vd.c.]	: 600-1500	
Max. Input Current Ad.c.]	: 26*9	26*14
Overvoltage Category (OVC)	: II for PV	
Rated Output Volt. [Va.c.]	: 3~ /PE 800	
Rated Output Freq. [Hz]	: 50/60	
Rated Output Power [kW]	: 208	255
Max. Output Curr. [Aa.c.]	: 150.1	184
Power Factor	: [-0.80, 0.80]	
Overvoltage Category (OVC)	: III for AC mains	

continued on page 0002

9

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Bruce Li
Bruce Li

Ginlong technologies Co., Ltd.
Zhang Kun

Date : 15.07.2020
Our ref. : QJL 01
Your ref.: Ruyi Pan

No.57 Jintong Road, Binhai,
(seafont), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Ref : R TÜV-Bauart-Zeichen o. Akkred. Nr.

Type of Equipment : Grid-connected PV Inverter
Model Designation : See Certificate
Certificate No. : R 50474441 0001
Report No. : 60392592 001

Dear Zhang Kun,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body



Bruce Li

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AN 50474442 0001

Report No.: 60392592 001

Holder: Ginlong technologies Co., Ltd.
No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Product: PV-Inverter
(Grid-connected PV Inverter)

Identification: Type Designation: Solis-208K-EHV-5G Solis-255K-EHV-5G
Serial Number : Engineering Sample
Remark(s) : Issued in conjunction with TÜV Rheinland
license R 50474441 0001-0002.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.



Date 15.07.2020

A handwritten signature in blue ink that reads 'Bruce Li'.

Bruce Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

Ginlong technologies Co., Ltd.
Zhang Kun

Date : 15.07.2020
Our ref. : QJL 01
Your ref.: Ruyi Pan

No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Grid-connected PV Inverter
Model Designation : See Certificate
Certificate No. : AN 50474442 0001
Report No. : 60392592 001

Dear Zhang Kun,


We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



Bruce Li

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询